

**AP - I**

**SEWAGE TREATMENT FACILITIES –  
DESIGN AND DRAWINGS**

**AP – I1**

---

**SMALL SEWAGE TREATMENT  
SYSTEMS (SSTS) FOR 80 PE**

## 1.0 DESIGN DATA

|                                    |   |  |
|------------------------------------|---|--|
| Population Equivalent              | = | 80 PE (maximum allowed PE)   |
| Waste Water Flow Per Person        | = | 0.225 m <sup>3</sup> / day. PE (or 225L / day)                           |
| Average Waste Water flow           | = | 18.00 m <sup>3</sup> /day = 0.21 x 10 <sup>-3</sup> m <sup>3</sup> /sec  |
| Peak Flow Factor (p)               | = | 4.7 x (80 ÷ 1000) <sup>-0.11</sup>                                       |
|                                    | = | 6.21   |
| Peak Hourly Flow (Q <sub>p</sub> ) | = | 111.69 m <sup>3</sup> /day = 1.29 x 10 <sup>-3</sup> m <sup>3</sup> /sec |
| Type of waste                      | = | Domestic   |
| Influent BOD <sub>5</sub>          | = | 250 ppm  |
| Influent SS                        | = | 300 ppm  |
| pH                                 | = | 5-8  |
| Influent BOD Loading               | = | 4.50 kg/day  |
| Influent SS Loading                | = | 5.40 kg/day  |

## 2.0 DESIGN OF RAW SEWAGE PUMP SUMP

### 2.1 Raw Sewage Pump Capacity

Effective Volume of Sump (wet well)

$$\begin{aligned}\text{Where } V &= TQ \div 4 \\ Q &= \text{Peak Flow} = 111.69 \text{ m}^3/\text{day} \\ T &= \text{Cycle time (6)} \\ V &= (6 \times 111.694) \div (4 \times 24 \times 60) = 0.116 \text{ m}^3\end{aligned}$$

Provide wet well size of 1.50 m diameter

$$\begin{aligned}\text{Required effective depth} &= 0.116 \text{ m}^3 \div \pi (1.5 / 2)^2 \\ &= 0.066 \approx 0.45 \text{ m (provided)}\end{aligned}$$

### 2.2 Pipe Sizing

$$\begin{aligned}\text{Pump capacity at peak flow} &= 1.29 \times 10^{-3} \text{ m}^3 / \text{sec} \\ &= 1.29 \text{ L/ sec}\end{aligned}$$

Desirable velocity in the discharge pipe at maximum pump discharge  $\leq 2.5$  m/sec (MS 1228).

Adopt velocity in discharge pipe as 2.0 m/sec

$$\text{Diameter, } D = \sqrt{\frac{1.29 \times 10^{-3} \text{ m}^3/\text{sec} \times 4}{\pi \times 2.0 \text{ m/sec}}}$$

$$= 0.029 \text{ m}$$

Provided pipe diameter = 100 mm (DI material or equivalent)

$$\begin{aligned}\text{Actual mean velocity, } V &= \frac{1.29 \times 10^{-3} \text{ m}^3/\text{sec} \times 4}{\pi \times 0.10 \text{ m} \times 0.10 \text{ m}} \\ &= 0.165 \text{ m/sec}\end{aligned}$$

$$\begin{aligned}\text{Other losses} &= \text{pipe} + \text{fitting}\end{aligned}$$

Losses through the pipe  $h_f$  (Hazen - William Formula)

$$V = 0.85 \times C \times R^{0.63} \times (h_f/L)^{0.54}$$

Losses through the fitting  $H_e$ , (Hazen - William Formula)

$$\begin{aligned}H_e &= K \times V^2 \div 2g \\ V &= \text{Mean velocity, } = 0.165 \text{ m/sec}\end{aligned}$$

|                     |   |  |
|---------------------|---|--|
| C                   | = | Hazen – William Coefficient for pipe = 90 for sewage                     |
| R                   | = | Hydraulic Radius = 0.025 m   |
| L                   | = | Length of pipe = 4.00 m  |
| K                   | = | Resistance coefficient for fitting & valve = 0.60                        |
| g                   | = | Acceleration due to gravity = 9.81 m/sec                                 |
| $(h_f/L)^{0.54}$    | = | $\frac{0.165 \text{ m / sec}}{\{0.85 \times 90 \times (0.025)^{0.63}\}}$ |
| $(h_f/L)$           | = | $(0.0220)^{1.85}$  |
| $h_f$               | = | $0.0009 \times 4.00 \text{ m} = 0.003 \text{ m}$                         |
| $H_e$               | = | $0.60 \times (0.165)^2 \div (2 \times 9.81)$                             |
|                     | = | 0.0008 m / per unit of fitting   |
| Total head          | = | static head + other losses   |
|                     | = | 3.00 m + 0.003 m + 0.0008 m  |
|                     | = | 3.0043 m   |
| Provided total head | = | 6.00 m   |

Provided 2 numbers of pumps, 1 working and 1 standby

∴ Each pump capacity = 5.75 L/s at 6.00 m total head = 0.345 m<sup>3</sup>/ min

### 2.3 Raw Sewage Pump Specification

|            |   |                              |
|------------|---|------------------------------|
| Type       | = | EBARA                        |
| Model      | = | 80 DVS 5.75 T                |
| Power      | = | 0.75 kW                      |
| Total Head | = | 6.00 m                       |
| Capacity   | = | 5.75 L/s > 1.29 L/s ..... OK |

Provided effective volume from 1<sup>st</sup> pump

|                                |   |   |
|--------------------------------|---|---|
| Start level to pump stop level | = | $\Pi (1.5/2)^2 \times 0.45 \text{ m(D)}$                          |
|                                | = | $0.795 \text{ m}^3 > 0.116 \text{ m}^3$                           |
| Retention time / time to fill  | = | $0.795 \text{ m}^3 \div 0.013 \text{ m}^3/ \text{ min}$           |
|                                | = | 63.63 min   |
| Time to empty                  | = | $0.795 \text{ m}^3 \div (0.345 - 0.013) \text{ m}^3/ \text{ min}$ |
|                                | = | 2.39 min  |
| Actual pump cycle at ADWF      | = | 63.63 min + 2.39 min  |
|                                | = | 66.02 min   |
| No. of start / stop            | = | $60 \div 66.02 \text{ min} = 0.91$                                |
|                                | = | 1 nos.  |

Note: The pumping cycle 6-15 start /stop per hour cannot be complied due to DGSS requirement; minimum dimension of pump is 1.5 mφ and minimum cut off level is 450mm.

## GOODWATER SYSTEM MODEL GWQ SA50

### 3.0 DESIGN DATA

|                              |   |  |
|------------------------------|---|--|
| DESIGN Process               | = | Conventional Activated Sludge Process          |
| Population Equivalent/ Units | = | 80 PE (maximum allowed PE)                     |
| Waste Water Flow Per Person  | = | 0.225 m <sup>3</sup> / day. PE (or 225lpcd)    |
| Average Waste Water flow     | = | 18.00 m <sup>3</sup> /day                      |
|                              | = | $0.21 \times 10^{-3} \text{ m}^3/ \text{ sec}$ |

|                             |   |  |
|-----------------------------|---|--|
| Peak Flow Factor (p)        | = | $4.7 \times (80 \div 1000)^{-0.11}$    |
|                             | = | 6.21                                   |
| Peak Flow (Q <sub>p</sub> ) | = | 111.69 m <sup>3</sup> /day             |
|                             | = | $1.29 \times 10^3$ m <sup>3</sup> /sec |
| Type of waste               | = | Domestic                               |
| Influent BOD <sub>5</sub>   | = | 250 ppm                                |
| Influent SS                 | = | 300 ppm                                |
| Efluent BOD <sub>5</sub>    | ≤ | 10 ppm                                 |
| Efluent SS                  | ≤ | 20 ppm                                 |

EQA BOD and SS value for Standard A = BOD 20 ppm an SS 50 ppm

Note: The following are not the discharged into the system; chemical of toxic/ corrosive nature, radio active products, metal, oil and grease.

#### 4.0 PRIMARY SEDIMENTATION TANK

|                   |   |  |
|-------------------|---|--|
| Retention Time    | = | 2.00 hrs   |
| Required Volume V | = | $(Q_{\text{peak}} \times \text{Retention time}) \div 24$ |
|                   | = | 9.31m <sup>3</sup>                                       |

##### a) Tank Specification (Refer Appendix 1)

|                 |   |  |       |
|-----------------|---|--|-------|
| Tank Diameter   | = | 2.40m  |       |
| Tank Radius     | = | 1.20m  |       |
| Tank Height     | = | 2.40m  |       |
| Provided Volume | = | 10.86m <sup>3</sup> > 9.31m <sup>3</sup> .... OK | ...ok |
| Check for HRT   | = | 2.33 hrs > 2.00 hrs...OK                         | ...ok |

#### 5.0 AERATION TANK

##### a) Design Parameter based on DGSS Guideline

|                                     |   |  |
|-------------------------------------|---|--|
| a. F/M Ratio                        | = | 0.25 - 0.50                                |
| b. HRT/hr.                          | = | 6-16                                       |
| c. Sludge Age/day (Q <sub>c</sub> ) | = | 5-10                                       |
| d. MLSS/ (mg/l)                     | = | 1500-3000                                  |
| e. MLVSS                            | = | 0.80 MLSS                                  |
| f. Oxygen Requirement               | = | 1.50 kgO <sub>2</sub> / kgBOD <sub>5</sub> |

##### b) Tank Volume (Required)

|                                |   |                            |
|--------------------------------|---|----------------------------|
| $V_R = (Q_A \times 8) \div 24$ | = | $(18.00 \times 8) \div 24$ |
|                                | = | 6.00m <sup>3</sup>         |

##### c) Tank Specification (Refer Appendix 1)

|                             |   |   |       |
|-----------------------------|---|---|-------|
| Tank Radius                 | = | 1.60m                                   |       |
| Tank Height                 | = | 2.35m                                   |       |
| Volume of the provided tank | = | 7.53m <sup>3</sup> > 6.00m <sup>3</sup> | ...ok |

$$\begin{aligned} \text{Check the provided HRT} &= (7.53 \div 18.00) \times 24 \\ \text{(Hydraulic Retention Time)} &= 10.04 \text{ hrs} \quad (6-16 \text{ hrs}) \end{aligned} \quad \dots ok$$

**d) Aeration Rate**

$$\begin{aligned} \text{Provided Air Rate} &= 1.50 \text{ kg O}_2/\text{BOD}_5 \text{ removed} \\ \text{Amount of BOD to be removed} &= 0.25 \text{ kg BOD/m}^3 - 0.01 \text{ kg BOD/m}^3 \\ &= 0.24 \text{ kg BOD/m}^3 \text{ of sewage} \\ \text{Total BOD}_5 \text{ per day} &= 18.00 \text{ m}^3/\text{day} \times 0.24 \text{ kg BOD/m}^3 \\ &= 4.32 \text{ kg BOD/day} \\ \text{Amount of O}_2 \text{ to supply (AOR)} &= 4.32 \text{ kg BOD/day} \times 1.50 \text{ kg O}_2/\text{BOD} \\ &= 6.48 \text{ kg O}_2/\text{day} \end{aligned}$$

**e) Field Conditions**

$$\begin{aligned} N \text{ (Field)} &= N_s (C_s - C_L) \div 9.17 \times (1.024)^{T-20} \times \alpha \\ N &= \text{Oxygen transferred in field condition kg O}_2/\text{hr} \\ N_s &= \text{Oxygen transfer under standard condition kg O}_2/\text{hr} \\ C_s &= \text{Dissolve oxygen saturation value at 25}^\circ\text{C} \text{ :- } 8.38 \text{ mg/l} \\ C_L &= 1-2 \text{ mg/l in mixed liquor (assume 2.00 mg/l)} \\ T &= \text{Temperature (}^\circ\text{C), } 25^\circ\text{C} \\ \alpha &= \text{Correlation Factor (0.85)} \end{aligned}$$

Therefore:-

$$\begin{aligned} 6.48 &= (N_s \times 6.38 \times 1.125 \times 0.85) \div 9.17 \\ N_s &= (6.48 \times 9.17) \div (6.38 \times 1.125 \times 0.85) \\ &= 9.74 \text{ kg O}_2/\text{day} = 0.007 \text{ kg O}_2/\text{min} \end{aligned}$$

**f) Air Volume Required**

$$\begin{aligned} \text{Assume O}_2 &= 23.20\% \text{ of air} \\ \text{Weight of 1m}^3 \text{ air} &= 1.20 \text{ kg} \\ \text{Air required normally} &= (0.007 \times 100) \div (23.20 \times 1.20) \\ &= 0.024 \text{ m}^3/\text{min} \\ \text{But efficiency of diffuser} &= 22\% \\ &= (0.024 \times 100) \div 22 \\ \text{Actual volume of air required} &= 0.110 \text{ m}^3/\text{min} \\ &= 110 \text{ l/min} \end{aligned}$$

**g) Air Diffuser Specification Refer Appendix B**

$$\begin{aligned} \text{Type} &= \text{Disc Diffuser} \\ \text{Model} &= \text{UNIFLEX U-330} \\ \text{Capacity} &= 0.10 \text{ m}^3/\text{min} \\ \text{Required Air Diffuser} &= (0.110 \div 0.10) = 1.10 \\ \text{No. Provided} &= 2 \end{aligned}$$

**h) Total Air Requirement**

$$\text{Aeration Tank} = 0.110 \text{ m}^3/\text{min}$$

**i) Blower Specification Refer Appendix C**

$$\text{Type} = \text{Hiblow Air Pump (2 units)}$$

|          |   |   |       |
|----------|---|---|-------|
| Model    | = | HP120   |       |
| Capacity | = | 0.120 m <sup>3</sup> /min > 0.110 m <sup>3</sup> /min | ...ok |
| Power    | = | 115 Watt  |       |

**j) Sludge Return Rate (RAS)**

|                  |   |  |
|------------------|---|--|
| MLSS             | = | 3.00 kg/m <sup>3</sup>                                   |
| MLSS ÷ (Cu-MLSS) | = | 3.00 kg/m <sup>3</sup> ÷ (7.00 - 3.00) kg/m <sup>3</sup> |
|                  | = | 0.75   |
|                  | = | 0.75 x 18.00 m <sup>3</sup> /day                         |
|                  | = | 13.50 m <sup>3</sup> /day                                |
|                  | = | 0.009 m <sup>3</sup> /min                                |

Note: Normally Return Sludge Rate will be - 75 - 100% of Q<sub>average</sub>

|                       |   |                                      |
|-----------------------|---|--------------------------------------|
| Recheck the F/M Ratio | = | (18.00 x 0.24) ÷ (2.4 x 7.53)        |
|                       | = | 0.24                                 |
| Check Organic Loading | = | (18.00 x 0.24) ÷ 7.53 m <sup>3</sup> |
|                       | = | 0.57 kgBOD/m <sup>3</sup> day        |

|              |   |   |
|--------------|---|---|
| Sludge Yield | = | 0.80 kg/kgBOD removed (Guidelines for Developers Volume IV) |
| BOD removed  | = | 0.24 x 18.00  |
|              | = | 4.32 kgBOD <sub>5</sub> /day                                |

|              |   |  |
|--------------|---|--|
| Sludge Yield | = | 0.80 kg x 4.32 kgBOD <sub>5</sub> /day |
|              | = | 3.46 kg/day                            |

|                            |   |              |
|----------------------------|---|--------------|
| SS in treated effluent     | = | 20 mg/l      |
| Solids in treated effluent | = | 18.00 x 0.02 |
|                            | = | 0.36 kg/day  |

|                                      |   |   |
|--------------------------------------|---|---|
| Sludge Age, $\theta_{\text{Sludge}}$ | = | <u>Total solids in aeration tank * MLSS</u>   |
|                                      | = | Excess sludge wasting/day + solid in effluent |
|                                      | = | <u>(7.53 x 3.00) kg</u>                       |
|                                      | = | (3.46 + 0.36) kg/day                          |
|                                      | = | 6 < 10 days                                   |

Waste Activated Sludge (WAS) =  $[(VT \times MLSS) \div \theta_{\text{Sludge}}] - (Q_{\text{ave}} - S_{\text{eff}}) \div Cu$

Where:-

|                          |   |  |
|--------------------------|---|--|
| VT                       | = | Volume of reactor (m <sup>3</sup> )                |
| MLSS                     | = | Mixed liquor suspended solids (kg/m <sup>3</sup> ) |
| $\theta_{\text{Sludge}}$ | = | Sludge age (day)                                   |
| Q <sub>ave</sub>         | = | Average flow (m <sup>3</sup> /day)                 |
| S <sub>eff</sub>         | = | Effluent suspended solids (kg/m <sup>3</sup> )     |
| Cu                       | = | Underflow concentration (kg/m <sup>3</sup> )       |
| Q <sub>WAS</sub>         | = | <u>[(7.53 x 3.00) ÷ 6] - (18.00 x 0.02)</u>        |

7

= 0.49 m<sup>3</sup>/day

## 6.0 CLARIFIER TANK (SECONDARY SEDIMENTATION TANK)

### a) Design Criteria

|  |   |                                       |
|--|---|---------------------------------------|
| Hydraulic detention time at Average Flow | > | 2.0 hrs                               |
| Weir Loading Rate                        | ≤ | 150 – 180 m <sup>3</sup> /m day       |
| Surface overflow                         | ≤ | 30 m <sup>3</sup> /m <sup>2</sup> day |
| Solid Loading Rate                       | ≤ | 50 kg/m <sup>2</sup> day              |

### b) Tank Specification (Refer Appendix 1)

|                                      |   |   |       |
|--------------------------------------|---|---|-------|
| Tank Radius                          | = | 0.80 m  |       |
| Tank Height                          | = | 2.30 m  |       |
| Volume of Sedimentation Tank         | = | 3.04 m <sup>3</sup>                             |       |
| Surface Area                         | = | 1.25 m <sup>2</sup>                             |       |
| Required Capacity (V <sub>SD</sub> ) | = | (Q <sub>A</sub> × 2.0 hrs) ÷ 24                 |       |
|                                      | = | (18.00 × 2.0) ÷ 24                              |       |
|                                      | = | 1.50 m <sup>3</sup> < 3.04 m <sup>3</sup>       | ...ok |
| Actual Detention Time (HRT)          | = | (3.04 × 2.0 hrs) ÷ 1.50                         |       |
|                                      | = | 4.05 hrs  | ...ok |
| Surface Overflow Rate (SOR)          | = | Q <sub>A</sub> ÷ Area                           |       |
|                                      | = | 18.00 m <sup>3</sup> /day ÷ 1.25 m <sup>2</sup> |       |
|                                      | = | 14.40 m <sup>3</sup> /m <sup>2</sup> .day       |       |
| Solid Loading Rate (SLR)             | = | Q <sub>A</sub> × 2.00 ÷ Area                    |       |
|                                      | = | (18.00 × 2.00) ÷ 1.25 m <sup>2</sup>            |       |
|                                      | = | 28.80 kg/m <sup>2</sup> .day                    |       |
| Weir Loading Rate                    | = | Q <sub>A</sub> ÷ Weir Length                    |       |
|                                      | = | (18.00 ÷ 0.60)                                  |       |
|                                      | = | 30.00 m <sup>3</sup> /m.day                     |       |



### c) Desludging Interval

|  |   |   |
|--|---|---|
| Consideration 60% of the Sedimentation Tank volume use for sludge accumulation |   |   |
| Sludge Production Rate   | = | 0.04 m <sup>3</sup> /PE.year  |
| Desludging Period  | = | $\frac{\text{Volume for Sludge Accumulation}}{\text{Sludge Production Rate}}$ |
|  | = | $\frac{0.60 \times 10.86 \text{ m}^3}{0.04 \times 80}$                        |
|  | = | 2.04 yrs  |



CALCULATION SHEET

Project Title : Volume Calculation of Aeration Tank  
 Drawing Number : SA 50 (80 PE)  
 Date : 22/3/2013  
 Page : 1/2



Radius = 1.20 m  
 Depth = 2.35 m  
 Diameter of Tank = 2.40 m  $\Phi$

Length of ① = 1.60 m  
 Length of ② = 0.80 m

$\cos \theta = \frac{0.40}{1.20}$   
 $\theta = \cos^{-1} 0.3333333$   
 $= 70.53^\circ$   
 $\beta = 90 - 70.53$   
 $= 19.47^\circ$



$1.44 = 0.16 + x^2$   
 $x^2 = 1.44 - 0.16$   
 $x = 1.131 \text{ m}$


## CALCULATION SHEET

Project Title : Volume Calculation of Aeration Tank  
 Drawing Number : SA 50 (80 PE)  
 Date : 22/3/2013  
 Page : 2/2

---

$$\begin{aligned}
 \text{Area of Sector A} &= 0.50 \times 0.40 \times 1.131 \\
 &= 0.226 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area of Sector B} &= 0.50 \left( \theta \times \frac{\pi}{180} \right) \times r \\
 &= 0.50 \left( 19.47 \times \frac{3.142}{180} \right) \times 1.44 \\
 &= 0.245 \text{ m}^2
 \end{aligned}$$



$$\begin{aligned}
 \text{Total Area of Sector A \& B} &= 0.226 + 0.245 \\
 &= (0.471 \text{ m}^2) \times 2 \\
 &= 0.942 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area of half circle} &= \frac{\pi}{2} \times 1.44 \\
 &= 2.26 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Therefore; Total area of A, B \& half circle; } A_1 &= 0.942 + 2.26 \\
 &= 3.204 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area of shaded segment} &= 0.50 \left[ \left( \theta \times \frac{\pi}{180} \right) - \sin \theta \right] \times r^2 \\
 &= 0.50 \left[ \left( 19.47 \times \frac{3.142}{180} \right) - 0.6285 \right] \times 1.44 \\
 &= 1.32 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Therefore Volume, } V_1 &= 3.204 \times 2.35 \\
 &= 7.53 \text{ m}^3
 \end{aligned}$$

$$\begin{aligned}
 \text{Volume, } V_2 &= 1.32 \times 2.30 \\
 &= 3.04 \text{ m}^3
 \end{aligned}$$



**AP – I2**

---

**SMALL SEWAGE TREATMENT  
SYSTEMS (SSTS) FOR 150 PE**

## 'SSTS Plant Design Calculation for 150 PE

### SIZING OF PUMP SUMP

#### BASIC DESIGN DATA

- POPULATION EQUIVALENT : 150 PE
- AVERAGE FLOW RATE : 33.75 m<sup>3</sup>/day = 0.00039m<sup>3</sup>/s  
(0.0234m<sup>3</sup>/min)
- PEAK FACTOR : 4.7 (PE/1000)<sup>-0.11</sup> = 5.80
- PEAK FLOW : 5.80 x 33.75.00 = 195.75 m<sup>3</sup>/day  
= 0.00226 m<sup>3</sup>/s  
(0.1360<sup>3</sup>/min)
  
- BOD CONCENTRATION (Influent) : 250 mg/l
- BOD LOADING : 8.4375 Kg/day
- MLSS CONCENTRATION (Influent) : 300 mg/l
- MLSS Aeration Tank : 4,250 mg/l
- MLVSS Aeration Tank : 3,400 mg/l

### TREATED EFFLUENT

The final effluent shall comply to the Standard A as stipulated by the Environment Quality (Sewerage and Industrial) Regulations 1979, Department of Environment, Ministry of Science, Technology and Environment i.e.

|                   |               |
|-------------------|---------------|
| BOD               | : Max 10 mg/l |
| COD               | : Max 60 mg/l |
| SS                | : Max 20 mg/l |
| NH <sub>3</sub> N | : Max 5 mg/l  |
| NO <sub>3</sub> N | : Max 10 mg/l |
| O&G               | : Max 2 mg/l  |

#### 1. PRIMARY SCREEN CHAMBER

|                             |   |
|-----------------------------|---|
| Average flow                | = 33.75 m <sup>3</sup> /day<br>= 0.00039 m <sup>3</sup> /s (0.0234 m <sup>3</sup> /min) |
| Clear Opening               | = 25 mm (0.025 m)   |
| Bar Width                   | = 10 mm (0.010m)  |
| Nos of Opening              | = 8   |
| Total Opening Areas         | = 8 x 0.025 = 0.20 m  |
| No of Bars                  | = 9   |
| Total Bar Area              | = 9 x 0.010 = 0.09 m <sup>2</sup>   |
| Total Screen Width Required | = 0.20 + 0.09 = 0.29 m  |
| Screen width provided       | = 0.30 m  |
| Total clear opening area    | = 0.025 m (Opening) x 8 Nos x<br>1.00 m (Width)<br>= 0.225 m <sup>3</sup>               |

Up stream velocity flow through at the screen channel at average flow:

$$= 33.75 \text{ m}^3/\text{day}$$

$$= \frac{0.00039 \text{ m}^3/\text{s}}{0.3 \times 1.00}$$

$$= 0.0013 \text{ m/s}$$

Up stream velocity flow through at the screen channel at peak flow

$$= \frac{0.0026 \text{ m}^3/\text{s}}{0.3 \times 1.00}$$

$$= 0.0086/\text{s}$$

Approach Velocity flow the screen chamber at average flow:

$$= \frac{0.0039 \text{ m}^3/\text{s}}{0.225 \text{ m}^2}$$

$$= 0.00173 \text{ m/s (Less than 0.3 m/s)}$$

Velocity flow through at the screen chamber bar peak flow:

$$= \frac{0.00226 \text{ m}^3/\text{s}}{0.225 \text{ m}^2}$$

$$= 0.010 \text{ m/s} < 0.8 \text{ m/s}$$

Head loss through a bar screen:

$$H = \frac{v^2 - v'^2}{2g} \times \frac{1}{0.7}$$

Where;

h = head loss

V = velocity through the bar screen

v = velocity upstream of bar screen

g Acceleration due to gravity

Head loss through a bar screen at average flow

$$h = \frac{0.00173^2 - 0.0013^2}{2(9.8)} \times \frac{1}{0.7}$$

$$h = 0.000000095 \text{ m}$$

Head loss through a bar screen at peak flow

$$h = \frac{0.010^2 - 0.0086^2}{2(9.8)} \times \frac{1}{0.7}$$

$$h = 0.00000189 \text{ m}$$

Estimated volume of Screening per volume of waste water

$$= 30 \text{ m}^3 / 10^6 \text{ m}^3$$

Design for weekly cleaning (7 days). Thus, quantity of screenings

$$= \frac{30}{10^6} \times 33.75 \times 7$$

$$= 0.0070 \text{ m}^3/\text{week}$$

Design Volume of basket

$$= 0.30 (L) \times 0.30 (W) \times 0.50 (D)$$

$$= 0.027m^3 > 0.0070 m^3$$

## 2. DESIGN OF PUMP SUMP

|   |   |   |
|---|---|---|
| Peak flow   | = | $195.75 m^3/day$                            |
|   | = | $0.00226m^3/s$                              |
| Pumps design flow                                     | = | $Q_{peak}$ (As per IWK Guideline)           |
|   | = | $0.00226 m^3/s$ (2.26 L/s)                  |
| Allow for 10 start / stop per hours                   |   |   |
| Thus volume of pump sump required                     | = | $\frac{Tq}{4}$                              |
|   | = | $\frac{60}{10} \frac{195.75}{24 \times 60}$ |
|   | = | $0.20 m^3$                                  |
| Effective volume provided, using 1500mm dia. Round MH | = | $1.50^2 \times 3.142 \times 0.45 (D)$       |
|   | = | $3.18m^3 > 0.20m^3$                         |
| Effective volume provided                             | = | $3.18m^3$                                   |

### 2.1 PUMPING CYCLE

|                             |   |                                      |
|-----------------------------|---|--------------------------------------|
| Average flow                | = | $33.75 \frac{m^3}{day} = 0.39l/s$    |
| Peak flow                   | = | $195.75 \frac{m^3}{day} = 2.26l/s$   |
| Level of Discharge Point    | = | 18.85 m                              |
| Level of Pump Cut-Off Point | = | 15.53                                |
| Static Head                 | = | 3.32 m                               |
| Discharge pipe of each pump | = | 100 mm (D.I)                         |
| Pipe areas                  | = | $3.14 j^2$                           |
|                             | = | $3.14 \left(\frac{0.10}{2}\right)^2$ |
|                             | = | $0.0079m^2$                          |

### HEAD LOSS COMPUTATION

|                     |   |  |
|---------------------|---|--|
| Static Head Adopted | = | 4.00m  |
| Dynamic Head        | = | Head loss due to numbers of short elbow 90° bends + Frictional loss in pipe + Velocity head loss |
|                     | = | $H_{fl} + H_{fm} + V^2/2g$   |

Fitting Head loss due to:

Numbers of fittings, valve and short elbow 90°bends:

| Item | Description  | Qty | K' Value | Amount |
|------|--------------|-----|----------|--------|
| 1    | 90 deg elbow | 1   | 0.29     | 0.29   |
| 2    | Taper        | 0   | 0.09     | 0      |
| 3    | Gate valve   | 1   | 0.12     | 0.12   |
| 4    | Check valve  | 1   | 1        | 1      |
|      |              |     |          | 1.41   |

$$H_{f1} = 'K' \text{ value} \times V^2/2g$$

| Flow (l/s) | m <sup>3</sup> /s | Velocity (V) | Head Loss |
|------------|-------------------|--------------|-----------|
| 0          | 0                 | 0.00         | 0.000     |
| 5          | 0.005             | 0.64         | 0.039     |
| 10         | 0.01              | 1.27         | 0.155     |
| 15         | 0.015             | 1.91         | 0.348     |
| 20         | 0.02              | 2.55         | 0.619     |
| 25         | 0.025             | 3.18         | 0.968     |
| 30         | 0.03              | 3.82         | 1.393     |

Frictional loss in Pipe by Manning's Formula:

$$H_{fm} = \frac{fm \times L \times V^2}{D \ 2g}$$

$$\text{Where } fm = \frac{124.6}{D} \times n^2$$

- $H_{fm}$  = Frictional Loss Head, m.
- $Fm$  = Friction Loss Co-efficient.
- $N$  = Roughness factor = 0.013 for New Ductile Iron Pipe.
- $L$  = Total pipe length, m.
- $D$  = Pipe inner diameter, m.
- $V$  = Average Velocity, m/sec.
- $g$  = Acceleration of free fall = 9.8 m/sec<sup>2</sup>
- $V^2/2g$  = Velocity Head, m.
- $D$  = 0.10 m.
- $L$  = 1.00 m.
- $n$  = 0.013.

Hence  $H_{fm}$

$$\text{Hence } H_{fm} = \frac{124.6 \times n^2 \times L \times V^2}{D^{1.333} \ 2g}$$



| Flow (l/s) | m <sup>3</sup> /s | Velocity (V) | Head Loss |
|------------|-------------------|--------------|-----------|
| 0          | 0                 | 0.00         | 0.000     |
| 5          | 0.005             | 0.64         | 0.009     |
| 10         | 0.01              | 1.27         | 0.038     |
| 15         | 0.015             | 1.91         | 0.085     |
| 20         | 0.02              | 2.55         | 0.150     |
| 25         | 0.025             | 3.18         | 0.235     |
| 30         | 0.03              | 3.82         | 0.338     |


$$H_{f1} = 'K' \text{ value} \times V^2/2g$$

Total System Head:

| Flow (l/s) | Static Head (m) | Fitting Loss due to 100 mm dia. Fittings | Fitting Loss due to 100 mm dia. Pipes | System Head |
|------------|-----------------|--|---------------------------------------|-------------|
| 0          | 4.00            | 0.000                                    | 0.000                                 | 4.000       |
| 5          | 4.00            | 0.039                                    | 0.009                                 | 4.048       |
| 10         | 4.00            | 0.155                                    | 0.038                                 | 4.192       |
| 15         | 4.00            | 0.348                                    | 0.085                                 | 4.433       |
| 20         | 4.00            | 0.619                                    | 0.150                                 | 4.770       |
| 25         | 4.00            | 0.968                                    | 0.235                                 | 5.202       |
| 30         | 4.00            | 1.393                                    | 0.338                                 | 5.731       |

System Curve:

| Flow (l/s) | System Head | Pump Head |
|------------|-------------|-----------|
| 0          | 4.000       | 8.3       |
| 5          | 4.048       | 6.6       |
| 10         | 4.192       | 5         |
| 15         | 4.433       | 3.4       |
| 20         | 4.770       | 2         |
| 25         | 5.202       | 0.9       |
| 30         | 5.731       | 0         |



Pump Recommended = 2 Numbers of 'EBARA' Raw Sewage Pump, Model:100 DML51.5; 1.50kW with discharge capacity of 12.00 l/s at operating head of 4.30 m. The peak flow of the system required is 2.26 l/s.

Velocity in 100mm diameter D.I discharge pipe:

$$\text{Velocity at discharge pipe} = \frac{0.012 \text{ m}^3/\text{s}}{0.00785 \text{ m}^2} = 1.52 \text{ m/s (Less than 2.50 m/s as per SPAN guideline)}$$

**TIME CYCLE**

- Level of Pump Start Point = 15.98 m
- Level of Pump Cut-Off Point = 15.53 m
- Level Difference in Between Start and Stop = 0.45 m

Based on average flow;

$$\begin{aligned} \text{Effective Vol. Provided} &= 3.18 \text{ m}^3 (3,180.00 \text{ Liter}) \\ \text{Filling time} &= 3.180 / 0.39 \text{ l/s} \\ &= 8153 \text{ s} \\ &= 135.90 \text{ min} \end{aligned}$$

$$\begin{aligned} \text{Dewatering time} &= 3,180.00 / (12.00 - 0.39 \text{ l/s}) \\ &= 273.90 \text{ s} \\ &= 4.56 \text{ min} \end{aligned}$$

$$\begin{aligned} \text{Total time required} &= (135.90 + 4.56) \text{ min} \\ &= 140.46 \text{ min} \end{aligned}$$

$$\begin{aligned} \text{Cycle} &= 60 / 140.46 \\ &= 0.42 \text{ times/hour} \end{aligned}$$

SECONDARY SCREEN CHAMBER

|                          |   |  |
|--------------------------|---|--|
| Average flow             | = | 33.75 m <sup>3</sup> / day                             |
|                          | = | 0.00039 m <sup>3</sup> /s (0.0234 m <sup>3</sup> /min) |
| Clear Opening            | = | 12 mm (0.012 m)  |
| Bar Width                | = | 10 mm (0.010 m)  |
| Nos of Opening           | = | 29   |
| Total Opening Areas      | = | 29 x 0.012 = 0.348 m <sup>2</sup>                      |
| No of Bars               | = | 30   |
| Total Bar Area           | = | 30 x 0.010 = 0.30 m <sup>2</sup>                       |
| Total Screen Width       | = | 0.348 + 0.30 = 0.648 m                                 |
| Screen Width provided    | = | 0.70 m   |
| Screen Length            | = | 0.5 m  |
| Total clear opening area | = | 30 x 0.012 = 0.360 m <sup>2</sup>                      |
|                          | = | 0.36 m <sup>2</sup> x 0.5 m (Length)                   |
|                          | = | 0.180 m <sup>2</sup>                                   |

Up stream velocity flow thru at screen chamber during Average Flow:

$$= \frac{0.00039m^3/s}{(0.70 \times 0.50)m^2}$$

$$= 0.0011 \text{ m/s (Less than 0.3 m/s)}$$

Up stream velocity flow thru at screen chamber during Peak Flow:

$$= \frac{0.00226m^3/s}{(0.70 \times 0.50)m^2}$$

$$= 0.00645 \text{ m/s} < 0.8 \text{ m/s}$$

Approach Velocity flow thru screen chamber during Average Flow:

$$= \frac{0.0039m^3/s}{0.18m^2}$$

$$= 0.00216 \text{ m/s (Less than 0.3 m/s)}$$

Velocity flow thru screen chamber during Peak Flow:

$$= \frac{0.00226m^3/s}{0.18m^2}$$

$$= 0.0125 \text{ m/s} < 0.8 \text{ m/s}$$

Head loss flow through bar screen at Average Flow:

$$h = \frac{0.00216^2 - 0.0011^2}{2(9.8)} \times \frac{1}{0.7}$$

$$h = 0.000000251 \text{ m}$$

Head loss through bar screen at Peak Flow:

$$h = \frac{0.0125^2 - 0.00645^2}{2(9.8)} \times \frac{1}{0.7}$$

$$h = 0.0032 \text{ m}$$

Calculation on half (1/2) blocked during the Peak Flow;  
Areas reduce to half (1/2)

$$= \frac{1}{2} \times 0.18$$

$$= 0.09 \text{ m}^2$$

Velocity flow through at the screen chamber bar @ Peak Flow;

$$= \frac{0.0125m^3/s}{0.09m^2}$$

$$= 1.388 \text{ m/s}$$

Head loss through bar screen at Peak Flow on half (1/2) block:

$$h = \frac{0,0032^2 - 0,000000251^2}{2(9.8)} \times \frac{1}{0.7}$$

$$h = 0.000000746 \text{ m}$$

Depth of water at 50% clogging = Max. Depth at peak flow + Head loss at 50% clogging  
= 0.000000746 + 0.0032  
= 0.00320m

The channel depth provided at the secondary screen is 500 mm (0.50m) which is sufficient.

FOR SSTS; MODEL: MFT-150 DETAIL CALCULATION, PLEASE REFER TO ATTACHMENT.

Muifatt mechanical IST Less than 150 PE:

Process: Anaerobic Septic Tank Supplemented with Activated Sludge Process

1. DESIGN DATA

| No. | Parameter   | Unit                     | Value/<br>Description                                  | Remarks   |
|-----|---|--------------------------|--|---|
| 1.  | Design population (PE)  | PE                       | 150  |   |
| 2.  | Type of waste   |                          | Domestic / organic                                     |   |
| 3.  | System Process  |                          | Aeration System for IST using Activated Sludge Process |   |
| 4.  | Influent BOD (ppm), Si : TSS (ppm), SSi                       | ppm                      | 250:   | 300 ppm = g/m <sup>3</sup> or 0.0111kg/m <sup>3</sup> |
| 5.  | Standard of Effluent  |                          | A  |   |
| 6.  | Effluent BOD (Average), Se: TSS (Average), SSe                | ppm                      | 10   | : 20 ppm=g/m <sup>3</sup> or x 0.001kg/m <sup>3</sup> |
| 7.  | BOD: TSS Removal Efficiency (%)                               | %                        | 96.00  | : 93.33   |
| 8.  | Daily Average Flow, Q <sub>avg</sub> (m <sup>3</sup> /PE.d)   | m <sup>3</sup> /PE.d     | 0.225  | 225 litre/s   |
| 9.  | Peak Flow Factor, 4.7 x (PE/1000) <sup>0.11</sup>             |                          | 5.79   |   |
| 10. | Total daily average Flow Q <sub>avg</sub> (m <sup>3</sup> /d) | m <sup>3</sup> /d        | 33.8   |   |
|     |   | m <sup>3</sup> /hr       | 1.4  |   |
|     |   | m <sup>3</sup> /min      | 0.023  |   |
|     |   | m <sup>3</sup> /s        | 0.0004   |   |
| 11. | Total Daily Peak Flow Q <sub>peak</sub> (m <sup>3</sup> /d)   | m <sup>3</sup> /d        | 195.4  |   |
|     |   | m <sup>3</sup> /h        | 8.1  |   |
|     |   | m <sup>3</sup> /min      | 0.136  |   |
|     |   | m <sup>3</sup> /s        | 0.0023   |   |
| 12. | Dissolved oxygen, DO (Table 5.12)                             | mg/l (g/m <sup>3</sup> ) | 1.0 (Date from aeration tank)                          |   |

|  |                          |             |                            |
|--|--------------------------|-------------|----------------------------|
| 13. Heterotropic yield coef, Yh (Table 5.12) | kg SS/kgBOD              | 0.80 mg BOD | SS/mg (Aeration tank data) |
| 14. MLSS                                     | mg/l (g/m <sup>3</sup> ) | 2300        | (Data from aeration tank)  |
| 15. MLVSS                                    | mg/l (g/m <sup>3</sup> ) | 1840        |                            |
| 16. Influent NH <sub>4</sub> -N              | mg/l (g/m <sup>3</sup> ) | 30.00       | mg/l                       |

### 1. Anaerobic Single Baffle Reactor Hybrid with Clarifier Settler

|   |   |                      |                                     |
|---|---|----------------------|-------------------------------------|
| Volume provided (6 to 24 hrs residence time) V1               | = | m <sup>3</sup>       | 28.92 (M &Eddy Chap.10-4)           |
| BOD Loading   | = | kg/m <sup>3</sup> .d | 0.29 < 2.2, o.k. M &Eddy Table 10-7 |
| Residence time/Hydraulic Retention Time (HRT)                 | = | hr                   | 20.56 (M &Eddy Chap.10-4)           |
| Clarifier Settler Compartment Surface Areas at Design TWL, A1 | = | m <sup>2</sup>       | 7.50                                |

### PROCESS DESIGN SEDIMENTATION

|  |   |   |
|--|---|---|
| Hydraulic Loading rate (HLR) to be <   |   | 4.50 m <sup>3</sup> /m <sup>2</sup> .d            |
| Hydraulic Loading Rate (HLR)   | = | Qa/ A1  |
|  | = | 4.5 m <sup>3</sup> /m <sup>2</sup> .d             |
| Design HLR < 4.5m <sup>3</sup> /m <sup>2</sup> .d (MS1220:1991): Thus design is OK |   |   |
| Average BOD <sub>5</sub> removal efficiency, Re1                                   | = | 50.0% ( M &Eddy Table 10-7)                       |
| BOD <sub>5</sub> removed   | = | BOD <sub>5</sub> x Re1                            |
|  | = | 4.21875 kg/d                                      |
| Remaining BOD <sub>5</sub> to aeration polishing                                   | = | BOD <sub>5</sub> x (100%-Re1)                     |
|  | = | 4.21875 kg/d                                      |
| Average SS removal efficiency, Re2   | = | 75%   |
| SS Removed   | = | SS x (100%-Re2)                                   |
|  | = | 2.53125 kg/d                                      |
| Sludge accumulation rate, Sr   | = | 0.04 m <sup>3</sup> /PE, yr                       |
| Total sludge accumulation, Sd  | = | Sr x PE   |
|  | = | 6.000 m <sup>3</sup> /yr                          |
| Retention time at end of 1 <sup>st</sup> year, t1                                  | = | V1 -Sd x 1  |
|  | = | 22.917 m <sup>3</sup> /Qa                         |
|  | = | 0.679 day   |
|  | = | 16.297 hrs within 4-24hrs range, M &Eddy Chap10-4 |
| Retention time at end of 2 <sup>nd</sup> year, t2                                  | = | V1 -Sd x 2  |
|  | = | 16.917 m <sup>3</sup> /Qa                         |
|  | = | 0.501 day   |
|  | = | 12.030 hrs within 4-24hrs range, M &Eddy Chap10-4 |

## 2. Conventional Activated Sludge Secondary Treatment Unit

### 2.1 AERATION TANK

Note: The Mechanical Aeration Polishing Calculation is carried out for 96.00% BOD Removal

Actual BOD removal efficiency required is 46.00% after anaerobic digestion

The aeration volume therefore can be 46.00% of that calculated here

The ratio is  $46.00\% / 96.00\% = 0.479$

Adjust the height of diffusers or location of the inclined plate to proportionate the aeration tank volume calculated here

Volume above the diffusers are effective for aerobic activated sludge biological treatment process.

Volume below diffusers are effective for anaerobic biological treatment process

The below kinetic coefficient shall be adopted.

|  |   |  |
|--|---|--|
| Influent BOD loading = $250 \text{ ppm} \times Q_{\text{avg}}$ | = | $0.25 \text{ kg/m}^3 \times 33.8 \text{ m}^3/\text{d}$ (250ppm Influent BOD <sub>5</sub> = $250 \text{m}^3 \times 10^6 \text{m}^3 \times 1000 \text{kg/m}^3$ ) |
|  | = | 8.44 kg/d  |
|  | = | 8.44 kg/d  |
| MLSS (Mixed Liquor Suspended Solid)                            | = | 2300 mg/L (2.3 kg/m <sup>3</sup> )   |
| Dissolved oxygen   | = | 1 ppm (0.001 kg/m <sup>3</sup> )   |
| Sludge yield   | = | 0.80 kg sludge produced / kg BOD <sub>5</sub> consumed (at 6hrs hyd.retention time)  |
| Underflow Concentration  | = | 4600 mg/l  |
| Density of Air D <sub>A</sub>                                  | = | 1.201 kg/m <sup>3</sup>  |
| % of O <sub>2</sub>  | = | 23.2%  |

#### Hydraulic Retention Time

Volume required =  $33.8 \text{ m}^3/\text{d} \times 6 \text{ hrs}/24\text{hrs}$  for system where only ammonia removal is required

= 8.44m<sup>3</sup>

Nos. of tank = 1

Adopt: Tank Size

Type of Aeration = Diffuser (Please input "Diffuser" or "Äerator")

Length without "l" Plate (L) = 2.973 m equivalent length for 4.028m<sup>2</sup> X-sectn wetted area

Top plan view length of "l" Plate (L<sub>p</sub>) = 924 mm

Total Internal Height = Tank dia (D) = 2.4 m

Water Depth (h) = 2 m

Freeboard = 0.4 m

Width at Water Level (W) = 1.79 m refer separate calculations

Nos. of tank = 1

Wetted Area of Circular X-sectn, A<sub>c</sub> = 4.028 m<sup>2</sup>

Vol at Circular X-sectn = A<sub>c</sub> \* L, V<sub>A11</sub> = 11.97524 m<sup>3</sup>

|   |   |   |
|---|---|---|
| Wetted Area of "I" X-sectn ( $A_p$ )                        | = | 3.532107 m <sup>2</sup>                                     |
| Vol. under "I" Plate for Aeration = $A_p/2 * L_p * V_{AT2}$ | = | 1.631833 m <sup>3</sup>                                     |
| Wetted Area of X-sectn below "I" Plate = $A_b$              | = | 0.495893 m <sup>2</sup>                                     |
| Vol. below bottom of "I" Plate = $A_b * L_p * V_{AT3}$      | = | 0.458206 m <sup>3</sup>                                     |
| Total Vol. if Aeration Tank $V_{AT}$                        | = | 14.065 m <sup>3</sup>                                       |
| Actual retention time                                       | = | 14.065 m <sup>3</sup> / 33.8 m <sup>3</sup> /d x 24 hrs / d |
|   | = | 10.002 hrs > 6hrs, O.K.                                     |

W/h recommended = 1:1 to 2.2:1

Calculation Notes for Above :

|   |   |   |
|---|---|---|
| Wetted X-Section area form water level to bottom of "I" Plate | = | 4.028 m <sup>2</sup> - ( $\pi * D^2 / 4$ ) - 4.028 m <sup>2</sup> |
|   | = | 3.532 m <sup>2</sup>  |
| Wetted Area of X-sectn below "I" Plate $A_b$                  | = | ( $\pi * D^2 / 4$ ) - 4.028 m <sup>2</sup>                        |
|   | = | 4.524 m <sup>2</sup> - 4.028 m <sup>2</sup>                       |
|   | = | 0.496 m <sup>2</sup>  |

F/M Ratio (Food/ Microorganism ratio)

F/M return shall be in the range of 0.25 - 0.50 d<sup>-1</sup>

|   |   |  |
|---|---|--|
| F/M = BOD loading x $Q_a / V_{AT} * MLSS$ | = | 250 ppm x 33.8 m <sup>3</sup> /d / 14.065 m <sup>3</sup> x 2300ppm |
|   |   | 0.26, 0.25 < F/M < 0.5, O.K  |
|   |   | O.K.   |

It is expected that by providing this volume of aeration tank, with the inflow BOD at 250 ppm, the excess microorganism above 2300 ppm will be staved of food and endogenous decay become the dominant process

Excess Sludge wasting (Sw)

|   |   |   |
|---|---|---|
| The sludge yield shall be                             |   | 0.80 kg dry solid / kg BOD consumed   |
| Sw = $Q_a * \text{BOD loading} * \text{sludge yield}$ |   | 33.8 m <sup>3</sup> /d x 0.25 kg/m <sup>3</sup> x 0.80 kg sludge /kg BOD consumed |
| Sw  | = | 6.75 kg/d   |

This is a theoretical value. In practice, there is no wasting and all sludge are residence in the aeration cum aerated digester sludge holding tank

Sludge Age  $\theta_s$

The sludge age shall be designed for 5~10 days based on daily wasting. There is no actual daily wasting. So, refer to the combined aerated digester sludge holding tank cum aeration tank sludge Age (Solids residence time) calculations

|                                      |   |   |
|--------------------------------------|---|---|
| $\theta_s = (V_p)(M_v - SS_e) / S_w$ | = | 14.07 m <sup>3</sup> x (2.3kg/m <sup>3</sup> - 0.02 kg/m <sup>3</sup> ) / 6.75 kg/d |
|                                      | = | 5 days (+/-) To increase MLSS or Volume of Aeration tank                            |
|                                      |   | OK  |

Note:  $V_p$  = Volume of Primary Aeration tank =  $V_{AT}$ ,  $M_v$  + Mixed Liquor Suspended Solid

Note: If there us daily wasting,

The hungry activated sludge of microorganism is designed to have minimum 5 days' residence time in the aeration tank at a concentration 2300 ppm to eat the food (BOD), grow and actively moving with abundant supply of oxygen from air diffusers and reduce the weight (and hence volume) of its body after growing and vigorous activities.

Theoretical Waste Activated Sludge  $Q_w$  (From the underflow of concentration  $C_u = 4600$  ppm)

$$Q_w = \frac{[(V_p \times M\theta_s) - (Q_a \times SS_e)]}{C_u} = 1.33 \text{ m}^3/\text{d}$$

Aerator BOD<sub>5</sub> Volumetric Loading

Aerator's BOD<sub>5</sub> volumetric loading shall be at 0.3-0.6kg/m<sup>3</sup>/d

$$\begin{aligned} &= \frac{Q_{avg}}{PE} \times BOD_{inf} \times PE / V_{AT} = \\ &= 0.225 \text{ m}^3/\text{d} \cdot PE \times (250\text{ppm} \times 150 \text{ PE}/14.06528 \\ &\quad \text{m}^3) \\ &= (0.05625 \text{ kg}/\text{d} \cdot PE \times 150 \text{ PE}/14.06528 \text{ m}^3) \\ &= 0.600 \text{ kg}/\text{d} \cdot \text{m}^3, 0.3 = \text{Aerator Volumetric} \\ &\quad \text{Loading} = <0.6, \text{OK (Note: } 250 \text{ ppm} = \\ &\quad 0.25\text{kg}/\text{m}^3) \end{aligned}$$

Recirculation Ratio

The allowable re-circulation ratio shall be 0.75 -1 (Table 5.12)

$$Q_{RAS} = [\text{MLSS}/\text{CU} - \text{MLSS}] \times Q_{AVG}$$

Where,

- Numerator MLSS = Original MLSS in the aeration tank will die off in one day and needed to be replenished.
- Denominator MLSS = Original MLSS in the aeration tank will die off in one day and needed to be replenished
- CU = Underflow concentration from final sedimentation tank is thicker than MLSS in aeration tank and will be withdrawn a proportion (compared to  $Q_{avg}$  rate of flow) to replenish the MLSS in aeration tank that is dying off
- CU - MLSS = Excess replenishing MLSS after subtracting the dying off MLSS from the replenishing CU

Therefore,

$$\begin{aligned} \frac{Q_{RAS}}{Q_{AVG}} &= \frac{\text{MLSS}}{(\text{CU} - \text{MLSS}) Q_{AVG}} \\ \frac{Q_{RAS}}{Q_{AVG}} &= \frac{\text{MLSS}}{(\text{CU} - \text{MLSS})} \\ &= \frac{2300}{(4600 - 2300)} \\ &= 1.00 \end{aligned}$$

The underflow sludge concentration shall be at 4.6 kg sludge/m<sup>3</sup> in order to maintain the MLSS

All requirement Rate

- Adopt oxygen requirement = 2 kg O<sub>2</sub> required /kg BOD & Ammonia substrate removal (growing phase)
- (i) The critical oxygen transfer,  $N_F$  = BOD & Ammonia substrate removal x  $Q_a$  x Oxygen Requirement
- = (0.25 - 0.01) kg/m<sup>3</sup> x 33.8 m<sup>3</sup>/d x 2.0 kg O<sub>2</sub>/ kg BOD removal
- = 16.20 kg O<sub>2</sub>/d
- = 0.68 kg O<sub>2</sub>/hr
- (ii) Oxygen transfer under field condition,  $N_s$  =  $(N_F \times 9.15) / [(C_S - C_L) \times 1.024^{(T^{20})} \times 0.85]$
- =  $\frac{0.68 \text{ kg O}_2/\text{hr} \times 9.15}{(8.38-1) \times (1.024) (25-20) \times 0.85}$



|   |   |   |
|---|---|---|
|   | = | 0.87 kg O <sub>2</sub> /hr                  |
| Vol. Air req for coarse bubble diffuser | = | Wt. of O <sub>2</sub> /(Da*0.232*Er)        |
|   | = | 0.87 / (1.201kg/m <sup>3</sup> *0.232*0.08) |
|   | = | 39.23 m <sup>3</sup> /hr                    |
|   | = | 0.65 m <sup>3</sup> /min                    |
| Vol. Air req for fine bubble diffuser   | = | Wt. of O <sub>2</sub> /(Da*0.232*Er)        |
|   | = | 0.65 / (1.201kg/m <sup>3</sup> *0.232*0.18) |
|   | = | 13.04 m <sup>3</sup> /hr                    |
|   | = | 0.22 m <sup>3</sup> /min                    |

2.2 Secondary Clarifier (ref. cl. 5.9 & Table 5.18, MS 1227 for HLR for Anaerobic Treatment)

This compartment served to separate the oxidized sludge generated and recycle back to the aeration tank to enhance the growth of the underflow MLSS concentration. The clear treated water is then discharged into the receiving watercourse through the outlet weir and pipe.

|   |   |  |
|---|---|--|
| No. of tank required NO <sub>T</sub>                  | = | 1, Since for PE =<1000, 1 clarifier is acceptable, ref. Table 5.18 |
| No. of tank provided NO <sub>TP</sub>                 | = | 1  |
| Proposed Geometrical Configurations of The Tanks (S): |   | Rectangular/Square Surface with Cylindrical Conduit Slopes or 60°  |

Surface loading or overflow rate (SOR)

Surface loading or overflow rate shall be max 30m<sup>3</sup>/m<sup>2</sup>/d at Q<sub>peak</sub>. Ref. Table 5.18 (Note: 40.04 m<sup>3</sup>/m<sup>2</sup>/d. Table 8-7. Metcalf & Ed)

Surface area req. per compartment = [Q<sub>peak</sub> m<sup>3</sup>/d / (30m<sup>3</sup>/m<sup>2</sup>/d)]/NO<sub>TP</sub> (Note: including the anaerobic effluent polishing flow)

|   |   |   |
|---|---|---|
|   | = | 195.4 m <sup>3</sup> /d / (m <sup>3</sup> /m <sup>2</sup> /d) / 1                           |
|   | = | 6.514 m <sup>2</sup>  |
| Length without “/” Plate (L)  | = | 3.282 m   |
| Top plan view length of “/” Plate (Lp)  | = | 0.24 mm   |
| Total Internal Height = Tank dia. (D)   | = | 2.40 m  |
| Water Depth (h)   | = | 2 m (Cl, 3.3.8 MSIG Vol. V, Table 3.2, Liquid depth = 1.22m - 2.6m)                         |
| Freeboard   | = | 0.40m   |
| Width at Water Level (W)  | = | 1.789 m (refer separate calculations)   |
| Nos. of tank  | = | 1   |
| Wetted Area of Circular X-sectn, A <sub>c</sub>                               | = | 4.028 m <sup>2</sup>  |
| Vol. at circular X-sectn = A <sub>c</sub> *L, V <sub>CL1</sub>                | = | 13.220 m <sup>3</sup>   |
| Wetted Area of “/” X-sectn (A <sub>p</sub> )                                  | = | 3.532 m <sup>2</sup>  |
| Vol. above “/” Plate for Clarifier = A <sub>p</sub> /2 * Lp, V <sub>CL2</sub> | = | 1.632 m <sup>3</sup>  |
| Wetted Area of X-sectn below “/” plate, A <sub>b</sub>                        | = | 0.496 m <sup>2</sup>  |
| Vol. below bot of “/” Plate = A <sub>b</sub> *O, V <sub>AT3</sub>             | = | 0 m <sup>3</sup>  |
| Total Vol. of clarifier tank, V <sub>CL</sub>                                 | = | 14.852 m <sup>3</sup>   |
| Height from top of tank to cover  | = | 0.15 m  |
| Surface Area req. based on Anaerobic Criteria HLR                             | = | 7.500 m <sup>2</sup>  |
| Required Surface Area Based on SOR <sub>peak</sub> & HLR                      | = | 7.500 m <sup>2</sup>  |
| Check Surface Area Provided   | = | 1.789 m x (3.282 m + 0.924 m) = 7.525 => 7.500 m <sup>2</sup> ok                            |
| Re-check actual surface loading:  |   | 195.4m <sup>3</sup> /d / (7.50m <sup>2</sup> x 1) = 26.06 m <sup>3</sup> /m <sup>2</sup> /d |

$\leq 30 \text{ M}^3/\text{M}^2/\text{d}$ , ok

### Weir Overflow Rate (WOR)

The weir loading shall be designed in the range of  $150\text{-}180 \text{ m}^3/\text{m}/\text{d}$  at peak flow

$$\begin{aligned}\text{Adopt WOR} &= 180 \text{ m}^3/\text{m}/\text{d} \\ \text{Weir length required} &= Q_p/\text{WOR} \\ &= \frac{195.4 \text{ m}^3/\text{d}}{180 \text{ m}^3/\text{m}/\text{d}} \\ &= 1.086 \text{ m per number of clarifier}\end{aligned}$$

### Solid Loading Rate (SLR)

The SLR shall be  $150 \text{ kg}/\text{m}^2/\text{d}$  at  $Q_{\text{peak}}$ ,  $< 50 \text{ kg}/\text{m}^2/\text{d}$  at  $Q_{\text{avg}}$

Check SLR peak : Alternative No. 1:

$$\begin{aligned}\text{SLR peak} &= \frac{Q_{\text{peak}} \times \text{incoming MLSS} / \text{nb VSS} + (Q_{\text{RAS}} + Q_{\text{WAS}}) \times \text{nb VSS}}{\text{Area of Clarifier}} \\ &= \frac{195.4 \text{ m}^3/\text{d} \times 2300 \text{ mg}/\text{l} + 35.08 \text{ m}^3/\text{d} \times 4600 \text{ mg}/\text{l}}{7.50 \text{ m}^2} \\ &= \frac{195.4 \text{ m}^3/\text{d} \times 4.6 \text{ kg}/\text{m}^3 + 35.08 \text{ m}^3/\text{d} \times 4.6 \text{ kg}/\text{m}^3}{7.50 \text{ m}^2} \\ &= 141.3845 \text{ kg}/\text{m}^2/\text{d} \\ &< 150 \text{ kg}/\text{m}^2/\text{d}, \text{ O.K.} \\ \text{SLR}_{\text{avg}} &= \frac{33.8 \text{ m}^3/\text{d} \times 2300 \text{ mg}/\text{l} + 35.08 \text{ m}^3/\text{d} \times 4600 \text{ mg}/\text{l}}{7.50 \text{ m}^2} \\ &= 31.87 \text{ kg}/\text{m}^2/\text{d} \\ &< 50 \text{ kg}/\text{m}^2/\text{d}, \text{ O.K.}\end{aligned}$$

### Scum Removal

The scum removal proposed for the STP is by means of manual scooping. The collected scum shall be returned to the aeration tank for further decomposition.

### Selection of Rate of Gravitational Return Sludge

(I) Required Rate of Gravitational Return Sludge Based on  $Q_{\text{RAS}}/Q_{\text{avg}} = 1$

$$\begin{aligned}\text{Rate of return} &= \frac{Q_{\text{RAS}} + Q_{\text{WAS}}}{1 \text{ Nos.}} = \frac{(1.00 \times 33.8 \text{ m}^3/\text{d}) + 1.33 \text{ m}^3/\text{d}}{1} \\ &= 35.08 \text{ m}^3/\text{d} \\ &= 0.024 \text{ m}^3/\text{min} \\ &= 0.00041 \text{ m}^3/\text{s}\end{aligned}$$

## 3.0 Sizing of air blower specification & Diffuser Specifications (Fine Bubble Diffuser System)

### 3.1 For Fine Bubble Diffuser System:

Total air required for sewage treatment system for one blower system is:

$$\begin{aligned}&= \text{air for aeration tank} \\ &= 0.217 \text{ m}^3/\text{min} \\ &= 0.217 \text{ m}^3/\text{min} \text{ (For 96.00 \% BOD removal)} \\ &= 0.100 \text{ m}^3/\text{min} \text{ (Proportionate For 46.00\% BOD removal)}\end{aligned}$$

Provision for Mixing and Aerobic Digestion in the Activated Sludge Compartment  
(iii) Clause 8.5.2 (d) MS 1228 : 1991

Diffuser = 0.35 l/ m<sup>3</sup>.s  
 Vol. Air req. for diffuser = 0.35 l/ m<sup>3</sup>.s  
 (per tank of sludge storage) = 0.3500 \* 6.832 m<sup>3</sup> \* 60.00 s  
 = 0.143468 m<sup>3</sup>/min Adopt 0.143/min.

**Propose Tube Aerator**

3.3.2

Type : Uniflex Fine Bubble Air Tube Diffuser  
 Model : UT-550  
 Material : EPDM  
 Dimension : 64mm dia. X 580 mm length

**Proposed Nos. of Uniflex Fine Bubble Tube Diffuser** l/min/diffuser =

Capacity : 300 l/min/diffuser = 0.3 m<sup>3</sup>/min/diffuser  
 Operating Flow Range : 150 - 250 l/min/diffuser, use 150l/min (170 mm H<sub>2</sub>O Pressure Loss) = 0.15 m<sup>3</sup>/min/diff.  
 Discharge : 0.143 m<sup>3</sup>/min  
 Nos. of diffuser required : 0.143 m<sup>3</sup>/min / (0.150 m<sup>3</sup>/min/diffuser) = 0.96 Diff.  
 Calculated Nos. of diffuser : 1  
 Provided No. of diffuser : 1 (Pressure Loss = 1\*170 mm 170 mm, H<sub>2</sub>O  
 Diffuser submergence Depth : 1000 mm (Discharge Pressure min 1500 mm AQ. A1 Blower, Density of sludge 1020 kg/ m<sup>3</sup>)

3.12

Type : EDI FlexAir T-Series Fine Bubble Air Tube Diffuser  
 Model : 62 x 762  
 Material : EPDM  
 Dimension : 66mm dia. X 762mm length

**Proposed EDI FlexAir T-Series Fine Bubble Air Tube Diffuser**

Capacity (Peak Air-flow) : 24 m<sup>3</sup>/hr/diffuser = 0.4 m<sup>3</sup>/min/diffuser  
 Design Air Flow Range : 5-17 m<sup>3</sup>/hr/diffuser, use 8.5 m<sup>3</sup>/hr (340mm H<sub>2</sub>O Pressure Loss) = 0.142 m<sup>3</sup>/min/diff.  
 Discharge : 0.143 m<sup>3</sup>/min  
 Nos. of diffuser required : 0.143 m<sup>3</sup>/min / (0.142 m<sup>3</sup>/min/diffuser) = 1.01 Diff.  
 Calculated Nos. of diffuser : 2  
 Provided No. of diffuser : 2 (Pressure Loss = 1 \* 300 mm 300 mm, H<sub>2</sub>O  
 Diffuser submergence depth : 1000 mm (Discharge Pressure min 1500 mm AQ. At Blower, Density of sludge 1020 kg/m<sup>3</sup>)

3.1.3

Type : HEXA Tubular EPDM Micro Pores Fine Bubble Air Tube Diffuser  
 Model : T-550  
 Material : EPDM  
 Dimension : 550 mm length

**Proposed HEXA Tubular EPDM Micro Pores Fine Bubble Air Tube Diffuser**

Capacity (Peak Air-flow) : 24 m<sup>3</sup>/hr/diffuser = 0.4 m<sup>3</sup>/min/diffuser  
 Design Air Flow Range : 1-12 m<sup>3</sup>/hr/diffuser, use 6 m<sup>3</sup>/hr (300mm H<sub>2</sub>O Pressure Loss)  
 Discharge : 0.143 m<sup>3</sup>/min

Nos. of diffuser required :  $0.143 \text{ m}^3/\text{min} / (0.100 \text{ m}^3/\text{min}/\text{diffuser}) = 1.43 \text{ Diff.}$   
 Calculated Nos. of diffuser : 2  
 Provided No. of diffuser : 2 (Pressure Loss =  $1 \times 300 \text{ mm} \quad 300 \text{ mm.H}_2\text{O}$   
 Diffuser submergence Depth : 1000 mm (Discharge Pressure min 1500 mm AQ.  
 AI Blower, Density of sludge  $1020 \text{ kg}/\text{m}^3$ )

#### 3.1.4

Type : Uniflex Fine Bubble Air Disc Diffuser  
 Model : U330  
 Material : ABS/EPDM  
 Dimension : 10"

#### Proposed Nos. of Uniflex Fine Bubble Air Disc Diffuser

Capacity :  $10 \text{ m}^3/\text{hr}/\text{diffuser} = 0.1167 \text{ m}^3/\text{min}/\text{diffuser}$   
 Operating Flow Range : 1-10  $\text{m}^3/\text{hr}/\text{diffuser}$ , use  $5 \text{ m}^3/\text{hr}$  ( $87 \text{ mm H}_2\text{O}$   
 Pressure Loss) =  $0.083 \text{ m}^3/\text{min}/\text{diff}$   
 Discharge :  $0.143 \text{ m}^3/\text{min}$   
 Nos. of diffuser required :  $0.143 \text{ m}^3/\text{min} / (0.083 \text{ m}^3/\text{min}/\text{diffuser}) = 1.72 \text{ Diff.}$   
 Calculated Nos. of diffuser : 2 Adopt  
 Provided No. of diffuser : 2 (Pressure Loss =  $1 \times 87 \text{ mm} \quad 87 \text{ mm.H}_2\text{O}$   
 Diffuser submergence Depth : 1000 mm (Discharge Pressure min 1500 mm AQ.  
 AI Blower, Density of sludge  $1020 \text{ kg}/\text{m}^3$ )

#### Proposed Disc Aerator

#### 3.1.5

Type : EDI Fine Bubble Air Disc Diffuser  
 Model : 9" Disc Diffuser High Cap  
 Material : EPDM  
 Dimension : 277mm Dia.

#### Proposed Nos. of EDI Fine Bubble Air Disc Diffuser

Capacity :  $18.7 \text{ m}^3/\text{hr}/\text{diffuser} = 0.312 \text{ m}^3/\text{min}/\text{diffuser}$   
 Operating Flow Range : 1.7-8.5  $\text{m}^3/\text{hr}/\text{diffuser}$ , use  $4.25 \text{ m}^3/\text{hr}$  ( $232 \text{ mm}$   
 $\text{H}_2\text{O}$  Pressure Loss) =  $0.071 \text{ m}^3/\text{min}/\text{diff}$   
 Discharge :  $0.143 \text{ m}^3/\text{min}$   
 Nos. of diffuser required :  $0.143 \text{ m}^3/\text{min} / (0.071 \text{ m}^3/\text{min}/\text{diffuser}) = 2.03 \text{ Diff.}$   
 Calculated Nos. of diffuser : 1 Not to adopt  
 Provided No. of diffuser : 1 (Pressure Loss =  $1 \times 232 \text{ mm} \quad 232 \text{ mm.H}_2\text{O}$   
 Diffuser submergence Depth : 1000 mm (Discharge Pressure min 1500 mm AQ.  
 AI Blower, Density of sludge  $1020 \text{ kg}/\text{m}^3$ )

#### Proposed Disc Aerator

#### 3.3.7

Type : HEXA Disc EPDM Micro Pores Fine Bubble Air Diffuser  
 Model : D250  
 Material : EPDM  
 Dimension : 250mm Dia.

#### Proposed HEXA Disc EPDM Micro Pores Fine Bubble Air Diffuser

Capacity :  $35 \text{ m}^3/\text{hr}/\text{diffuser} = 0.583 \text{ m}^3/\text{min}/\text{diffuser}$   
 Operating Flow Range :  $6.00 \text{ m}^3/\text{hr}/\text{diffuser}$ , use  $6 \text{ m}^3/\text{hr}$  ( $232 \text{ mm}$

|                             |  |
|-----------------------------|--|
|                             | $H_2O$ Pressure Loss) = 0.100 m <sup>3</sup> /min/diff   |
| Discharge                   | : 0.143 m <sup>3</sup> /min  |
| Nos. of diffuser required   | : 0.143 m <sup>3</sup> /min / (0.100 m <sup>3</sup> /min/diffuser) = 1.43 Diff.                        |
| Calculated Nos. of diffuser | : 2 Adopt  |
| Provided No. of diffuser    | : 2 (Pressure Loss = 1*232mm 232 mm.H <sub>2</sub> O   |
| Diffuser submergence Depth  | : 1000 mm (Discharge Pressure min 1500 mm AQ.<br>AI Blower, Density of sludge 1020kg/ m <sup>3</sup> ) |

### 3.1.7

#### Proposed Air Blower Specification for Coarse Bubble Diffuser System

|                    |   |  |                                 |
|--------------------|---|--|---------------------------------|
| Model              | : | TSB-50 Bore 50A                            | RSR-50K (50)                    |
| Capacity           | : | 0.143   0.78 m <sup>3</sup> /min @ 770 rpm | 1.26 m <sup>3</sup> .min @ 1240 |
| Power              | : | 0.64 kW                                    | 1.5kW                           |
| Discharge Pressure | : | 0.15 kgf/cm <sup>2</sup>                   | 2 kgf/cm <sup>2</sup>           |
| Nos. of Unit       | : | 2 units (1 duty, 1 standby)                | 2 units (1 duty, 1 standby)     |









**AP – I3**

**OIL & GREASE TRAP DESIGNS**

---

# Perangkap Minyak - GTS02

## SPESIFIKASI



2016 Model Baru,  
Tidak lagi masalah sumbat, bau busuk.

Model: GTS02

Kadar Aliran (minit) : 12 GPM

Hidangan Harian : 40-150

Saiz Paip (mm) : 40

Saiz Perangkap Minyak : 17" (L) x 12" (W) x 12" (H) inchi

Kapasiti Maksimum sisa dan minyak diperangkap : 20 liter

Kapasiti Maksimum sehingga limpahan : 40 liter

Material: Keluli 304 Tidak Berkarat 0.8 mm

Kesesuaian Kegunaan : Kopitiam/ Cafeteria/ Perumahan/  
Restaurant / Bawah sinki




R018/15




Cap Dagangan:






**Front view - Inlet**




**Back view - outlet**




**Left view**

**Specifications**


**Model:** GTS02  
**Material:** Stainless Steel 304  
**Thickness:** 0.8 mm  
**Inlet pipe size:** 1 ½ inch length 3"  
**Outlet pipe size:** 1 ½ inch length 3"  
**Flow rate:** 12 GPM  
**Capacity:** 40 Liter  
**SIRIM:** YES  
**Patent:** YES  
**Trade Mark:** EJAU  
**Warranty:** 5 Years  
**Ready Stock:** YES  
**Delivery:** Between 3 days  
**Own Factory:** YES, In Selangor



**Top view**



**ISO view**



**Right view**


\* In keeping with our policy of updating products we reserve the right to make improvements or changes.

**KUALITI ALAM HIJAU (M) SDN BHD**

|                      |   |   |                                  |
|----------------------|---|---|----------------------------------|
| <b>DRAWING FOR :</b> | <b>DRAWING DESCRIPTION :</b><br>Grease Interceptor          | <b>DATE :</b> 1/6/2015  | <b>Drawn by :</b> Syharul        |
|                      | <b>Model:</b> GTS02<br><b>Material:</b> Stainless Steel 304 | <b>NOTE :</b><br>All dimension in MM unless otherwise specified | <b>Checked by :</b> Tan Kok Hua  |
|                      |   |   | <b>Approved by :</b> Tan Kok Hua |

# GREASE INTERCEPTOR INSTALLATION GUIDE

UNDERSINK  
INSTALLATION



## KUALITI ALAM HIJAU (M) SDN BHD

|                      |   |   |                                  |
|----------------------|---|---|----------------------------------|
| <b>DRAWING FOR :</b> | <b>DRAWING DESCRIPTION :</b><br>Material : Stainless Steel 304 Non Rusted | <b>DATE :</b> 30/4/2014   | <b>Drawn by :</b> Syahrul        |
|                      |   | <b>NOTE :</b><br>All dimension in MM unless otherwise specified | <b>Checked by :</b> Jackson Wong |
|                      |   |   | <b>Approved by :</b> TAN         |



# Installation Guide

## GTS02 GREASE TRAP

To Join Inlet and Outlet

40 mm UPVCL

40 mm UPVCL

40 mm UPVC Socket

40 mm UPVC PTL

40 mm UPVCT

40mm UPVC Socket

40 mm UPVC Pipe 2 meter

40 mm UPVCL

40 mm UPVC PTL

White Tape

40 mm UPVCL

Use  
40 mm  
Socket

### Basic Installation Item:



1. 40 mm UPVC L x 4 unit
2. 40 mm UPVC PT L x 2 unit
3. 40 mm UPVC T x 1 unit
4. 40 mm UPVC Socket x 2 unit
5. 40 mm UPVC Pipe 2 meter
6. White Tape small x 2 rol

### Other item:

- a)PVC Gam
- b)Saw for cutting PVC

# Perangkap Minyak - GTA350

## SPESIFIKASI



Model: GTA350

Kadar Aliran (minit) : 50GPM

Hidangan Harian : 400 to 600

Saiz Paip (mm) : 3"

Saiz Perangkap Minyak : 32" (L) x 22" (W) x 25" (H) (Inch)

Kapasiti Maksimum sisa dan minyak diperangkap : 176 Liter

Kapasiti Maksimum sehingga limpahan : 262 Liter

Material: Keluli 304 Tidak Berkarat

Kesesuaian Kegunaan : R.Mamak / Workshop /




SIRIM TESTED


Cap Dagangan:









**Front view - Inlet**




**Back view - outlet**




**Left view**



**Top view**



**ISO view**



**Right view**

**Specifications**

**Model:** GTA350  
**Material:** Stainless Steel 304  
**Thickness:** 0.8 mm  
**Inlet pipe size:** 3" inch length 4"  
**Outlet pipe size:** 3" inch length 4"  
**Flow rate:** 50 GPM  
**Capacity:** 262 Liter  
**SIRIM:** YES  
**Patent:** YES  
**Trade Mark:** EJAU  
**Warranty:** 5 Years  
**Ready Stock:** YES  
**Delivery:** Between 3 days  
**Own Factory:** YES, In Selangor

**KUALITI ALAM HIJAU (M) SDN BHD**

**DRAWING FOR :**

**DRAWING DESCRIPTION :**  
 Material : Stainless Steel 304 Non Rusted


**DATE :** 30/4/2014

**NOTE :**  
 All dimension in MM unless otherwise specified

**Drawn by :** Liza

**Checked by :** Jackson

**Approved by :** Marizan



CROSS SECTION VIEW



**KUALITI ALAM HIJAU (M) SDN BHD**

|   |   |   |                                  |
|---|---|---|----------------------------------|
| <b>DRAWING FOR :</b><br>North South Green Resources | <b>DRAWING DESCRIPTION :</b><br>Material : Stainless Steel 304 Non Rusted | <b>DATE :</b> 30/4/2014   | <b>Drawn by :</b> Liza           |
|   |   | <b>NOTE :</b><br>All dimension in MM unless otherwise specified | <b>Checked by :</b> Jackson Wong |
|   |   |   | <b>Approved by :</b> Marizan     |



# Perangkap Minyak - GTA3500

## SPESIFIKASI



Model: GTA3500

Kadar Aliran (minit) : 500 GPM

Hidangan Harian : 12000 to 15000

Saiz Paip (mm) : 6"

Saiz Perangkap Minyak : 87" (L) x 56"(W) x 62"(H) (Inch)

Kapasiti Maksimum sisa dan minyak diperangkap : 3877 Liter

Kapasiti Maksimum sehingga limpahan : 4839 Liter

Material: Keluli 304 Tidak Berkarat


Kesesuaian Kegunaan : Kilang / Kanteen / Hotel




SIRIM TESTED

Cap Dagangan:







**Front view - Inlet**




**Back view - outlet**




**Left view**



**Top view**



**ISO view**




**Right view**

**Specifications**

Model: **GTA3500**  
 Material: Stainless Steel 304  
 Thickness: 1.0 mm  
 Inlet pipe size: 6" inch length 4"  
 Outlet pipe size: 6" inch length 4"  
 Flow rate: 500 GPM  
 Capacity: 4839 Liter  
  
 SIRIM: YES  
 Patent: YES  
 Trade Mark: EJAU  
 Warranty: 5 Years  
 Ready Stock: YES  
 Delivery: Between 3 days  
 Own Factory: YES, In Selangor

**KUALITI ALAM HIJAU (M) SDN BHD**

|                      |   |   |                              |
|----------------------|---|---|------------------------------|
| <b>DRAWING FOR :</b> | <b>DRAWING DESCRIPTION :</b><br>Material : Stainless Steel 304 Non Rusted | <b>DATE :</b> 30/4/2014   | <b>Drawn by :</b> Liza       |
|                      |   | <b>NOTE :</b><br>All dimension in MM unless otherwise specified | <b>Checked by :</b> Jackson  |
|                      |   |   | <b>Approved by :</b> Marizan |



CROSS SECTION VIEW

**KUALITI ALAM HIJAU (M) SDN BHD**

|                      |   |   |                                  |
|----------------------|---|---|----------------------------------|
| <b>DRAWING FOR :</b> | <b>DRAWING DESCRIPTION :</b><br>Material : Stainless Steel 304 Non Rusted | <b>DATE :</b> 30/4/2014   | <b>Drawn by :</b> Liza           |
|                      |   | <b>NOTE :</b><br>All dimension in MM unless otherwise specified | <b>Checked by :</b> Jackson Wong |
|                      |   |   | <b>Approved by :</b> Marizan     |

**AP - J**

**QUAL2K**

## Appendix J: Water Quality Modelling

### 1. QUAL2K MODEL

The water quality model for Segment 2B (Sg. Serendah to Sg. Selangor) was established using the QUAL2K software developed by Chapra *et al.* (2006). QUAL2K is a stream water quality model that is a modernized version of the QUAL2E model that was developed by Brown and Barnwell (1987). QUAL2K is :

- One dimensional. The channel is assumed to be well-mixed vertically and laterally.
- The system supports branching - A mainstem river with branched tributaries.
- Steady state hydraulics. Non-uniform, steady flow is simulated.
- Diel water-quality kinetics. All water quality variables are simulated on a diel time scale.
- Heat and mass inputs. Point and non-point loads and withdrawals are simulated.

The QUAL2K framework includes the following elements:

- Software Environment and Interface. QUAL2K is implemented within the Microsoft Windows environment. Numerical computations are programmed in Fortran 90. Excel is used as the graphical user interface. All interface operations are programmed in the Microsoft Office macro language: Visual Basic for Applications (VBA).
- Model segmentation. QUAL2E segments the system into river reaches comprised of equally spaced elements. QUAL2K also divides the system into reaches and elements. However, in contrast to QUAL2E, the element size for QUAL2K can vary from reach to reach. In addition, multiple loadings and withdrawals can be input to any element.
- Carbonaceous BOD speciation. QUAL2K uses two forms of carbonaceous BOD to represent organic carbon. These forms are a slowly oxidizing form (slow CBOD) and a rapidly oxidizing form (fast CBOD).
- Chemical Oxygen Demand (COD) cannot be modeled.
- Anoxia. QUAL2K accommodates anoxia by reducing oxidation reactions to zero at low oxygen levels. In addition, denitrification is modeled as a first-order reaction that becomes pronounced at low oxygen concentrations.
- Sediment-water interactions. Sediment-water fluxes of dissolved oxygen and nutrients are simulated internally rather than being prescribed. That is, oxygen (SOD) and nutrient fluxes are simulated as a function of settling particulate organic matter, reactions within the sediments, and the concentrations of soluble forms in the overlying waters.
- Bottom algae. The model explicitly simulates attached bottom algae. These algae have variable stoichiometry.
- Light extinction. Light extinction is calculated as a function of algae, detritus and inorganic solids.
- pH. Both alkalinity and total inorganic carbon are simulated. The river's pH is then computed based on these two quantities.
- Pathogens. A generic pathogen is simulated. Pathogen removal is determined as a function of temperature, light and settling.

- Reach specific kinetic parameters. QUAL2K allows the user to specify many of the kinetic parameters on a reach-specific basis.

## 2. RIVER SEGMENTATION

The QUAL2K model requires the river to be represented as a series of reaches. These represent stretches of river that have constant hydraulic characteristics (e.g., slope, bottom width, etc.). The reaches are numbered in ascending order starting from the headwater of the river's main stem. Both point and non-point sources and withdrawals (abstractions) can be positioned anywhere along the channel's length.

For systems with tributaries, the reaches are numbered in ascending order starting at reach 1 at the headwater of the main stem. When a junction with a tributary is reached, the numbering continues at that tributary's headwater. Both the headwaters and the tributaries are also numbered consecutively following a sequencing scheme similar to the reaches. The major branches of the system (that is, the main stem and each of the tributaries) are referred to as segments. This distinction has practical importance because the software provides plots of model output on a segment basis.

### 2.1 River Representation

A 33.31 km stretch of the rivers - from Sg. Serendah (approx. 0.18 km upstream of the Serendah Komuter Station) to about 0.87 km downstream of the water intake of SSP1 along Sg. Selangor – traversing through Sg. Garing and Sg. Sembah. The hydraulic schematic model of rivers modelled is shown in **Figure 1**.

### 2.2 Headwaters

The model has one headwater. A headwater is the upper limit of the model but do not necessarily represent the upper limit of the catchment. Each headwater has an upper catchment area which provides the inflows that drive the model. The headwater of the model is labeled as HW0.

The details of the headwater are as follows:

|                                   |                                  |
|-----------------------------------|----------------------------------|
| Head-water ID                     | : 0                              |
| Headwater name                    | : HW0                            |
| River name                        | : Sg. Serendah                   |
| Reach No.                         | : 1                              |
| Coordinates                       | : 3°22'36.75"N<br>101°36'57.53"E |
| Catchment area (km <sup>2</sup> ) | : 13.5 km <sup>2</sup>           |

## 2.3 Reaches

Reaches are sections of the river that have uniform hydraulic characteristics. The three main factors governing the flow discharge ( $Q_0$ ) in a reach of a river are the flow cross-sectional area governed by the flow depth ( $y_0$ ) and geometry of the river cross-section, the river channel bed slope ( $S$ ) and the Manning's roughness coefficient ( $n$ ) (**Table 1**), which is a measure of the channel boundary resistance to water flow.

$$Q_0 = f(y_0, \text{Slope}, \text{Manning's } n', \text{Geometry})$$

Manning's Equation:

$$Q_0 = \frac{M}{n} A_0 R_0^{2/3} S_0^{1/2}$$

$M = 1.49$  imperial

1.00 metric

$A$  = flow area

$R$  = hydraulic radius

$S$  = bed slope

Each segment of the model was classified and divided into reaches according to its hydraulic characteristics. A separate reach was established whenever a significant change in the hydraulic characteristics was observed. The channel slopes were calculated from the measured elevation at each reach.

The model has 9 reaches (**Table 2**). The determination of reaches was made by field surveys of project site, secondary data and satellite images wherein the following features were noted :

- Bottom width to determine the flow area ( $A$ ) during low flow. On-site measurements of the channel width were made, where possible. Otherwise, they were estimated from survey drawings
- Channel shape (side slope)
- On-site GPS measurement of the elevations at the boundary of river reaches, to estimate the channel bed slope of the reach.

The Manning's roughness coefficient ( $n$ ) was estimated based on observations during site visits to the project site and by comparing the conditions of the channel bottom and wetted perimeter at the channel sides with the values given in the QUAL2K Documentation Manual by Chapra *et. al* (2006) (**Table 1**).

**Table 1 The Manning's Roughness Coefficient for Open Channel Surfaces**

| Material                       | $n$        |
|--------------------------------|------------|
| <b>Man-made channels</b>       |            |
| Concrete                       | 0.012      |
| Gravel bottom with sides:      |            |
| Concrete                       | 0.020      |
| Mortared stone                 | 0.023      |
| Riprap                         | 0.033      |
| <b>Natural stream channels</b> |            |
| Clean, straight                | 0.025-0.04 |
| Clean, sinding and some weeds  | 0.03-0.05  |
| Weeds and pools, winding       | 0.05       |
| Mountain streams with boulders | 0.04-0.10  |
| Heavy brush, timber            | 0.05-0.20  |

Source: (from Chow *et al.* (1988), cited in QUAL2K Documentation Manual)



**Table 2 Reaches in the Water Quality Model**

| <b>Reach Label</b> | <b>Reach No</b> | <b>Headwater Reach</b> | <b>Length (km)</b> | <b>Upstream (km)</b> | <b>Down-stream (m)</b> | <b>Manning n</b> |
|--------------------|-----------------|------------------------|--------------------|----------------------|------------------------|------------------|
| R1                 | 1               | Yes                    | 1.59               | 33.31                | 31.72                  | 0.035            |
| R2                 | 2               | No                     | 5.92               | 31.72                | 25.80                  | 0.035            |
| R3                 | 3               | No                     | 5.24               | 25.80                | 20.56                  | 0.035            |
| R4                 | 4               | No                     | 3.44               | 20.56                | 17.12                  | 0.035            |
| R5                 | 5               | No                     | 2.18               | 17.12                | 14.94                  | 0.035            |
| R6                 | 6               | No                     | 3.21               | 14.94                | 11.73                  | 0.035            |
| R7                 | 7               | No                     | 3.39               | 11.73                | 8.34                   | 0.035            |
| R8                 | 8               | No                     | 2.94               | 8.34                 | 5.40                   | 0.035            |
| R9                 | 9               | No                     | 5.40               | 5.40                 | 0.00                   | 0.035            |



Figure 1a Hydraulic Schematic for Segment 2B (Construction Phase)





Figure 1b Hydraulic Schematic for Segment 2B (Operation Phase)



### 3. Flows

Three types of flow values were used in the model:

- a) flow obtained from field measurements to establish the baseline model;
- b) peak discharge of 2-year-return-period calculated using DID's Hydrological Procedure No. 4 for Scenario 2 during the construction phase;
- c) 7Q10 low flow calculated using DID's Hydrological Procedure No. 12 for Scenario 2 during the operation phase.

### 4. Pollution Sources

#### 4.1 Point sources

Tributaries (streams and drains) were modeled as point loads (see Section 2.1 above). The quantity of discharge for the tributaries was calculated using their drainage areas and the average annual low flows while the quality of discharge was determined from field sampling. In total, 7 point sources were included in the model during Construction Phase and 1 point source was included during Operation Phase. The details of the point sources modeled are given in Table 3.

**Table 3 Point Sources input for the Model**

| Point source              | Description            | Headwater ID | Location (km) | Inflow (m <sup>3</sup> /s) |
|---------------------------|------------------------|--------------|---------------|----------------------------|
| <b>Construction Phase</b> |                        |              |               |                            |
| PS1                       | ROW Sediment 1         | 0            | 29.81         | 5.9383                     |
| PS2                       | S13 – Serendah Station | 0            | 29.47         | 1.0700                     |
| PS3                       | ROW Sediment 2         | 0            | 25.06         | 2.4127                     |
| PS4                       | ROW Sediment 3         | 0            | 22.41         | 2.5896                     |
| PS5                       | ROW Sediment 4         | 0            | 19.61         | 2.4230                     |
| PS6                       | Hotspot S15            | 0            | 18.50         | 0.4700                     |
| PS7                       | Hotspot S16            | 0            | 14.94         | 8.8790                     |
| <b>Operation Phase</b>    |                        |              |               |                            |
| PS1                       | Serendah Station SSTS  | 0            | 29.93         | 0.0023                     |

#### 4.2 Diffused sources

Diffused sources of pollution were input into the entire stretch of the model. Diffused sources entered the reaches directly. The locations and area of diffuse sources were determined from land use maps and satellite images.

The diffused pollution loadings were determined based on the Event Mean Concentration (EMC) method. Generally, the estimation of pollutant input is based on the concept that land use may be regarded as a direct indicator of the amount of pollutant released annually or, that the concentration of the pollutant which is discharged out of the catchment may be estimated. For calculating pollution loads, the formula below is applied:

$$L = R \times EMC \times A \times C_v / 100$$

where,

$L$  = Annual pollutant load (kg/year)

$R$  = Mean annual rainfall (mm/year)

$EMC$  = Event mean concentration (mg/L)

$A$  = Catchment area (ha)

$C_v$  = Area-weighted volumetric runoff coefficient for the whole catchment.

Each type of land use will however generate different pollution characteristics and loads and therefore EMC values will need to be determined for the individual land use type.

Table 4 shows the recommended mean EMC value for various pollutants and land uses (MSMA 2nd Edition, DID, 2012) while Table 5 shows the input of diffuse sources into the model. Diffuse flows are established from flow balance calculations.

**Table 4 Mean EMC Values for Selected Land Uses**

| Pollutant |      | Land Use    |            |          |         |
|-----------|------|-------------|------------|----------|---------|
| Parameter | Unit | Residential | Commercial | Industry | Highway |
| TSS       | mg/L | 128.00      | 122.00     | 166.00   | 80.00   |
| Turbidity | NTU  | 122.00      | 96.00      | 147.00   | 69.00   |
| TDS       | mg/L | 131.00      | 43.00      | 137.00   | 38.00   |
| pH        | -    | 6.46        | 6.77       | 6.66     | 6.57    |
| BOD       | mg/L | 17.90       | 22.90      | 19.30    | 14.90   |
| COD       | mg/L | 97.00       | 134.00     | 140.00   | 81.00   |
| AN        | mg/L | 0.73        | 0.85       | 1.00     | 0.44    |

Source: MSMA 2<sup>nd</sup> Edition, DID, 2012

**Table 5 Diffuse Sources input for the Model**

| Diffuse Load Name | Reach no. | Location upstream (km) | Location downstream (km) | Diffuse Abstraction (m <sup>3</sup> /s) | Diffuse Inflow (m <sup>3</sup> /s) |
|-------------------|-----------|------------------------|--------------------------|---|------------------------------------|
| D1                | 1         | 33.310                 | 31.720                   | -                                       | 6.5207                             |
| D2                | 2         | 31.720                 | 25.800                   | -                                       | -                                  |
| D3                | 3         | 25.800                 | 20.560                   | -                                       | 0.2020                             |
| D4                | 4         | 20.560                 | 17.120                   | -                                       | 1.5975                             |
| D5                | 5         | 17.120                 | 14.940                   | -                                       | -                                  |
| D6                | 6         | 14.940                 | 11.730                   | -                                       | 1.4358                             |
| D7                | 7         | 11.730                 | 8.340                    | -                                       | 9.3494                             |
| D8                | 8         | 8.340                  | 5.400                    | 0.5263                                  | -                                  |
| D9                | 9         | 5.400                  | 0.000                    | 18.1950                                 | -                                  |

## 5. Reaction Rates

The default values for water quality kinetics and reaction provided in the QUAL2K model were used for the Perwaja Drainage model (**Table 6**).

**Table 6 Default Values for Water Quality Kinetics and Reaction Rates**

| <b>Parameter</b>                         | <b>Value</b>     | <b>Units</b>        | <b>Symbol</b>  |
|--|------------------|---------------------|----------------|
| <i>Stoichiometry:</i>                    |                  |                     |                |
| Carbon                                   | 40               | gC                  | gC             |
| Nitrogen                                 | 7.2              | gN                  | gN             |
| Phosphorus                               | 1                | gP                  | gP             |
| Dry weight                               | 100              | gD                  | gD             |
| Chlorophyll                              | 1                | gA                  | gA             |
| <i>Inorganic suspended solids:</i>       |                  |                     |                |
| Settling velocity                        | 1.304            | m/d                 | $v_i$          |
| <i>Oxygen:</i>                           |                  |                     |                |
| Reaeration model                         | O'Connor-Dobbins |                     |                |
| User reaeration coefficient $\alpha$     | 0                |                     | $\alpha$       |
| User reaeration coefficient $\beta$      | 0                |                     | $\beta$        |
| User reaeration coefficient $\gamma$     | 0                |                     | $\gamma$       |
| Temp correction                          | 1.024            |                     | $\theta_a$     |
| Reaeration wind effect                   | None             |                     |                |
| O2 for carbon oxidation                  | 2.69             | gO <sub>2</sub> /gC | $r_{oc}$       |
| O2 for NH <sub>4</sub> nitrification     | 4.57             | gO <sub>2</sub> /gN | $r_{on}$       |
| Oxygen inhib model CBOD oxidation        | Exponential      |                     |                |
| Oxygen inhib parameter CBOD oxidation    | 0.60             | L/mgO <sub>2</sub>  | $K_{socf}$     |
| Oxygen inhib model nitrification         | Exponential      |                     |                |
| Oxygen inhib parameter nitrification     | 0.60             | L/mgO <sub>2</sub>  | $K_{sona}$     |
| Oxygen enhance model denitrification     | Exponential      |                     |                |
| Oxygen enhance parameter denitrification | 0.60             | L/mgO <sub>2</sub>  | $K_{sodn}$     |
| Oxygen inhib model phyto resp            | Exponential      |                     |                |
| Oxygen inhib parameter phyto resp        | 0.60             | L/mgO <sub>2</sub>  | $K_{sop}$      |
| Oxygen enhance model bot alg resp        | Exponential      |                     |                |
| Oxygen enhance parameter bot alg resp    | 0.60             | L/mgO <sub>2</sub>  | $K_{sob}$      |
| <i>Slow CBOD:</i>                        |                  |                     |                |
| Hydrolysis rate                          | 4.999            | /d                  | $k_{hc}$       |
| Temp correction                          | 1.047            |                     | $\theta_{hc}$  |
| Oxidation rate                           | 5                | /d                  | $k_{des}$      |
| Temp correction                          | 1.047            |                     | $\theta_{des}$ |
| <i>Fast CBOD:</i>                        |                  |                     |                |
| Oxidation rate                           | 5                | /d                  | $k_{dc}$       |
| Temp correction                          | 1.047            |                     | $\theta_{dc}$  |
| <i>Organic N:</i>                        |                  |                     |                |
| Hydrolysis                               | 0                | /d                  | $k_{hn}$       |
| Temp correction                          | 1.07             |                     | $\theta_{hn}$  |

|  |                 |                             |                 |
|--|-----------------|-----------------------------|-----------------|
| Settling velocity                          | 0               | m/d                         | $V_{on}$        |
| <i>Ammonium:</i>                           |                 |                             |                 |
| Nitrification                              | 1.649           | /d                          | $K_{na}$        |
| Temp correction                            | 1.07            |                             | $\square_{na}$  |
| <i>Nitrate:</i>                            |                 |                             |                 |
| Denitrification                            | 0               | /d                          | $K_{dn}$        |
| Temp correction                            | 1.07            |                             | $\square_{dn}$  |
| Sed denitrification transfer coeff         | 0               | m/d                         | $V_{di}$        |
| Temp correction                            | 1.07            |                             | $\square_{di}$  |
| <i>Organic P:</i>                          |                 |                             |                 |
| Hydrolysis                                 | 0               | /d                          | $K_{hp}$        |
| Temp correction                            | 1.07            |                             | $\square_{hp}$  |
| Settling velocity                          | 1.999           | m/d                         | $V_{op}$        |
| <i>Inorganic P:</i>                        |                 |                             |                 |
| Settling velocity                          | 0               | m/d                         | $V_{ip}$        |
| Inorganic P sorption coefficient           | 0.073           | L/mgD                       | $K_{dpi}$       |
| Sed P oxygen attenuation half sat constant | 1.831           | mgO <sub>2</sub> /L         | $K_{spi}$       |
| <i>Phytoplankton:</i>                      |                 |                             |                 |
| Max Growth rate                            | 2.5             | /d                          | $K_{gp}$        |
| Temp correction                            | 1.07            |                             | $\square_{gp}$  |
| Respiration rate                           | 0.1             | /d                          | $K_{rp}$        |
| Temp correction                            | 1.07            |                             | $\square_{rp}$  |
| Excretion rate                             | 0               | /d                          | $K_{ep}$        |
| Temp correction                            | 1.07            |                             | $\square_{dp}$  |
| Death rate                                 | 0               | /d                          | $K_{dp}$        |
| Temp correction                            | 1               |                             | $\square_{dp}$  |
| External Nitrogen half sat constant        | 15              | ugN/L                       | $K_{sPp}$       |
| External Phosphorus half sat constant      | 2               | ugP/L                       | $K_{sNp}$       |
| Inorganic carbon half sat constant         | 2.00E-05        | moles/L                     | $K_{sCp}$       |
| Light model                                | Half saturation |                             |                 |
| Light constant                             | 57.6            | langleys/d                  | $K_{Lp}$        |
| Ammonia preference                         | 25              | ugN/L                       | $K_{hnxp}$      |
| Subsistence quota for nitrogen             | 0               | mgN/mgA                     | $q_{0Np}$       |
| Subsistence quota for phosphorus           | 0               | mgP/mgA                     | $q_{0Pp}$       |
| Maximum uptake rate for nitrogen           | 0               | mgN/mgA/d                   | $\square_{mNp}$ |
| Maximum uptake rate for phosphorus         | 0               | mgP/mgA/d                   | $\square_{mPp}$ |
| Internal nitrogen half sat constant        | 0               | mgN/mgA                     | $K_{qNp}$       |
| Internal phosphorus half sat constant      | 0               | mgP/mgA                     | $K_{qPp}$       |
| Settling velocity                          | 0.15            | m/d                         | $V_a$           |
| <i>Bottom Algae:</i>                       |                 |                             |                 |
| Growth model                               | Zero-order      |                             |                 |
| Max Growth rate                            | 999.991         | mgA/m <sup>2</sup> /d or /d | $C_{gb}$        |
| Temp correction                            | 1.07            |                             | $\square_{gb}$  |


|                                       |                 |                    |                  |
|---------------------------------------|-----------------|--------------------|------------------|
| First-order model carrying capacity   | 1000            | mgA/m <sup>2</sup> | $a_{b,max}$      |
| Respiration rate                      | 1               | /d                 | $K_{rb}$         |
| Temp correction                       | 1.07            |                    | $\square_{rb}$   |
| Excretion rate                        | 0.5             | /d                 | $K_{eb}$         |
| Temp correction                       | 1.05            |                    | $\square_{db}$   |
| Death rate                            | 0.09            | /d                 | $K_{db}$         |
| Temp correction                       | 1.07            |                    | $\square_{db}$   |
| External nitrogen half sat constant   | 0.052           | ugN/L              | $K_{SPb}$        |
| External phosphorus half sat constant | 96.379          | ugP/L              | $K_{SNb}$        |
| Inorganic carbon half sat constant    | 1.00E-05        | moles/L            | $K_{SCb}$        |
| Light model                           | Half saturation |                    |                  |
| Light constant                        | 76.319          | langleys/d         | $K_{Lb}$         |
| Ammonia preference                    | 99.982          | ugN/L              | $K_{hnxb}$       |
| Subsistence quota for nitrogen        | 2.524           | mgN/mgA            | $q_{0N}$         |
| Subsistence quota for phosphorus      | 0.002           | mgP/mgA            | $q_{0P}$         |
| Maximum uptake rate for nitrogen      | 149.913         | mgN/mgA/d          | $\square_{mN}$   |
| Maximum uptake rate for phosphorus    | 5.009           | mgP/mgA/d          | $\square_{mP}$   |
| Internal nitrogen half sat constant   | 0.384           | mgN/mgA            | $K_{qN}$         |
| Internal phosphorus half sat constant | 0.102           | mgP/mgA            | $K_{qP}$         |
| <i>Detritus (POM):</i>                |                 |                    |                  |
| Dissolution rate                      | 7.179           | /d                 | $K_{dt}$         |
| Temp correction                       | 1.07            |                    | $\square_{dt}$   |
| Fraction of dissolution to fast CBOD  | 1.00            |                    | $F_f$            |
| Settling velocity                     | 0.236           | m/d                | $V_{dt}$         |
| <i>Pathogens:</i>                     |                 |                    |                  |
| Decay rate                            | 0.8             | /d                 | $K_{dx}$         |
| Temp correction                       | 1.07            |                    | $\square_{dx}$   |
| Settling velocity                     | 1               | m/d                | $V_x$            |
| Light efficiency factor               | 1.00            |                    | $\square_{path}$ |
| <i>pH:</i>                            |                 |                    |                  |
| Partial pressure of carbon dioxide    | 347             | ppm                | $p_{CO2}$        |
| <i>Constituent i</i>                  |                 |                    |                  |
| First-order reaction rate             | 0               | /d                 |                  |
| Temp correction                       | 1               |                    | $\square_{dx}$   |
| Settling velocity                     | 0               | m/d                | $V_{dt}$         |
| <i>Constituent ii</i>                 |                 |                    |                  |
| First-order reaction rate             | 0               | /d                 |                  |
| Temp correction                       | 1               |                    | $\square_{dx}$   |
| Settling velocity                     | 0               | m/d                | $V_{dt}$         |
| <i>Constituent iii</i>                |                 |                    |                  |
| First-order reaction rate             | 0               | /d                 |                  |
| Temp correction                       | 1               |                    | $\square_{dx}$   |
| Settling velocity                     | 0               | m/d                | $V_{dt}$         |

## 6. Model Calibration

The water quality model was calibrated using field data (flow and dissolved oxygen) collected in August 2017.

**Figure 2** shows the predicted and the observed water quality along the rivers modelled. Some variance in the correlation between the predicted and observed data can be expected, as the model predicts a steady-state water quality whereas the observed data captures the water quality at a particular point in time. The limitations of the model are due to estimations of hydraulic and water quality data along sub-tributaries and incomplete pollution source data, such as inflows and effluent quality of the pollution sources. Reaction rates and kinetics also play an important role in determining the outcome of the model.

**Figure 2 Model calibration of the water quality model for Flow and Dissolved Oxygen**





## 7. SCENARIO MODELED

For both Construction and Operation Phases, in addition to the baseline scenario which simulates the changes in the water quality without the proposed project, two scenarios were modeled for this study. During the Construction Phase, the scenarios are:

i. Scenario 1 (with Mitigation Measures)

The first scenario with the proposed project models the changes in water quality as a result of sediment contribution from the ROW and station construction sites of the Project. The maximum sediment contribution from the Project is 50 mg/L with implementation of mitigation measures.

ii. Scenario 2 (Worst Case with Mitigation Measures):

The Worst Case Scenario simulates the outcome when rainfall event occurs and sediment runoff increases drastically. The sediment contribution from the Project is 1,000 mg/L with implementation of mitigation measures at peak discharge of 2-year-return-period.

During the Operation Phase, the scenarios are:

i. Scenario 1 (Normal)

Sewage treatment systems will discharge effluent that meets Standard A limits of the Environmental Quality (Sewage) Regulations 2009 at discharge flow of 0.0023 m<sup>3</sup>/s.

ii. Scenario 2 (Worst Case):

Sewage treatment systems will discharge effluent that meets Standard A limits of the Environmental Quality (Sewage) Regulations 2009 at discharge flow of 0.0023 m<sup>3</sup>/s but during 7Q10 low flow conditions.


## 8. MODELING RESULTS

The impact of the Project to the water quality of the river during the Construction Phase is shown in **Chart 1** while during Operation Phase the results are shown in **Charts 2 to 4** below.


## 9. ASSUMPTIONS AND LIMITATIONS OF THE MODEL

The water quality model is assumed to be reflective of the actual conditions based on calibration of selected parameters only, i.e. dissolved oxygen, BOD, pH, and TSS. Default values of the water quality kinetics, reaction rates and constants have been used, as local data is very limited.


**Chart 1 Impact of Proposed Project on Suspended Solids Concentration during Construction Phase**




**Chart 2 Impact of Proposed SSTS Effluent Discharge on Suspended Solids Concentration during Operation Phase**



**Chart 3 Impact of Proposed SSTS Effluent Discharge on Biochemical Oxygen Demand (BOD) Concentration during Operation Phase**



**Chart 4 Impact of Proposed SSTS Effluent Discharge on Ammoniacal Nitrogen Concentration during Operation Phase**



This page has been intentionally left blank.